

Equipment for Special Circumstances



Wye/Open Delta Bank

- » Typical dimensions of equipment (low style):
40 inches long by 36 inches wide by 26 inches tall
- » Typical dimensions of equipment (regular style):
40 inches long by 36 inches wide by 34 inches tall
- » Typical concrete foundation dimensions for equipment:
60 inches by 80 inches
- » Required easement for equipment's installation and operation: **13 feet by 10 feet**



Underground Switch Cabinet

- » Typical dimensions of equipment:
67 inches long by 75 inches wide by 50 inches tall
- » Typical concrete foundation dimensions for equipment:
82 inches by 90 inches
- » Required easement for equipment's installation and operation: **20 feet by 20 feet**



Underground Feeder Splice Box

- » Typical dimensions of equipment:
120 inches long by 60 inches wide by 41 inches tall
- » Required easement for equipment's installation and operation: **7 feet by 22 feet**



Three Phase Transformer

- » The dimensions may vary:
49 inches long by 64 inches wide by 47 inches tall or
87 inches long by 100 inches wide by 71 inches tall
- » Typical concrete foundation dimensions for transformer:
60 inches by 80 inches or **106 inches by 106 inches**
- » Required easement for equipment's installation and operation:
10 feet by 10 feet or **20 feet by 20 feet**