

Gulf Power Company

Business Heating Ventilation & Air Conditioning ("HVAC")

Program Tables

Effective: November 2, 2020

Table of Contents

Disclaimers..... 2

Chiller Incentive Tables..... 3

DX Incentive Tables..... 6

ERV Incentive Tables..... 9

DCV Incentive Tables..... 8

DCV Kitchen Hood Incentive Table..... 10

Gulf Power Business HVAC Program Tables

Disclaimers

The issuance of a rebate by Gulf Power Company under the Program shall not be considered or relied upon by the customer to be confirmation that: (i) the customer has selected the proper HVAC system; and/or (ii) that any of the underlying work performed by the Contractor was done properly pursuant to the manufacturer recommendations and specifications, building codes, other applicable laws, industry standards or individual contract requirements. Gulf Power Company does not participate in or approve the selection of the HVAC system and Gulf Power Company does not manage or provide oversight of the work performed by the Contractor selected by the customer. It is the sole responsibility of the customer to investigate and select an HVAC system that is appropriate for the specific application, manage the Contractor they select to perform the work and to take the necessary precautions they deem prudent to ensure the equipment and work meets their expectations.

Gulf Power Company does not provide any supervision, control or instructions to Contractor regarding the means and methods for performing any work that might be eligible for a rebate. This is entirely the responsibility of the Contractor and likewise the sole responsibility of the customer to manage and inspect the work performed by the Contractor.

Gulf Power Business HVAC Program Tables

Chiller Incentive Tables

		<i>Gulf Power Incentives Air Cooled Chillers Path A</i>		<i>Gulf Power Incentives Air Cooled Chillers Path B</i>	
		Air Cooled with Matching Condenser		Air Cooled with Matching Condenser	
Chiller Efficiency Required IPLY ==>		Tons ≥ 150	Tons < 150	Tons ≥ 150	Tons < 150
		≥ 14.0 IPLY (≤ 0.857 KW/Ton)	≥ 13.700 IPLY (≤ 0.876 KW/Ton)	≥ 16.100 IPLY (≤ 0.745 KW/Ton)	≥ 15.800 IPLY (≤ 0.759 KW/Ton)
		Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton
EER	KW/TON				
15.00	0.80	81.480	81.48	91.77	91.77
14.81	0.81	79.380	79.38	89.67	89.67
14.63	0.82	77.280	77.28	87.57	87.57
14.46	0.83	75.180	75.18	85.47	85.47
14.29	0.84	73.080	73.08	83.37	83.37
14.12	0.85	70.980	70.98	81.27	81.27
13.95	0.86	68.880	68.88	79.17	79.17
13.79	0.87	66.780	66.78	77.07	77.07
13.64	0.88	64.680	64.68	74.97	74.97
13.48	0.89	62.580	62.58	72.87	72.87
13.33	0.90	60.480	60.48	70.77	70.77
13.19	0.91	58.380	58.38	68.67	68.67
13.04	0.92	56.280	56.28	66.57	66.57
12.90	0.93	54.180	54.18	64.47	64.47
12.77	0.94	52.080	52.08	62.37	62.37
12.63	0.95	49.980	49.98	60.27	60.27
12.50	0.96	47.880	47.88	58.17	58.17
12.37	0.97	45.780	45.78	56.07	56.07
12.24	0.98	43.680	43.68	53.97	53.97
12.12	0.99	41.580	41.58	51.87	51.87
12.00	1.00	39.480	39.48	49.77	49.77
11.88	1.01	37.380	37.38	47.67	47.67
11.76	1.02	35.280	35.28	45.57	45.57
11.65	1.03	33.180	33.18	43.47	43.47
11.54	1.04	31.080	31.08	41.37	41.37
11.43	1.05	28.980	28.98	39.27	39.27
11.32	1.06	26.880	26.88	37.17	37.17
11.21	1.07	24.780	24.78	35.07	35.07
11.11	1.08	22.680	22.68	32.97	32.97
11.01	1.09	20.580	20.58	30.87	30.87
10.91	1.10	18.480	18.48	28.77	28.77
10.81	1.11	16.380	16.38	26.67	26.67
10.71	1.12	14.280	14.28	24.57	24.57
10.62	1.13	12.180	12.18	22.47	22.47
10.53	1.14	10.080	10.08	20.37	20.37
10.43	1.15			18.27	18.27
10.34	1.16			16.17	16.17
10.26	1.17			14.07	14.07
10.17	1.18			11.97	11.97
10.08	1.19			9.87	9.87

Notes:

1. Certification required by manufacturer to latest released AHRI Standard 550/590
2. Chiller efficiencies do not include kW of chill water pumps
3. Required AHRI range of rating conditions - chilled water circuit 44F chilled water temp,
Flow rate 2.4 gpm/ton Air cooled condenser @ ambient air temp 95F
4. Special class/size not AHRI certified must have manufacturer verified specifications at AHRI conditions
& approved by Gulf Power HVAC specialist or contractor representative
5. Efficiencies higher than maximum table ratings will be computed by Gulf Power
6. Air Cooled chillers without condensers must be rated with matching condensers and comply with the air
cooled chiller efficiency requirements

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Water Cooled Chillers Path A</i>											
KW Reduction Based on ASHRAE 90.1 National Energy Code Minimum Efficiency Standards											
		Water Cooled Centrifugal					Water Cooled Positive Displacement				
		Tons ≥ 600	400 ≤ Tons < 600	300 ≤ Tons < 400	150 ≤ Tons < 300	Tons < 150	Tons ≥ 600	300 ≤ Tons < 600	150 ≤ Tons < 300	75 ≤ Tons < 150	Tons < 75
Required IPLV ==>	≤ 0.500	≤ 0.500	≤ 0.52	≤ 0.550	≤ 0.550	≤ 0.500	≤ 0.520	≤ 0.54	≤ 0.56	≤ 0.600	
Chiller Efficiency EER KW/TON	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton
26.7	0.45	23.10	23.10	23.10	33.60	33.60	23.10	33.60	44.10	56.70	63.00
26.1	0.46	21.00	21.00	21.00	31.50	31.50	21.00	31.50	42.00	54.60	60.90
25.5	0.47	18.90	18.90	18.90	29.40	29.40	18.90	29.40	39.90	52.50	58.80
25.0	0.48	16.80	16.80	16.80	27.30	27.30	16.80	27.30	37.80	50.40	56.70
24.5	0.49	14.70	14.70	14.70	25.20	25.20	14.70	25.20	35.70	48.30	54.60
24.0	0.50	12.60	12.60	12.60	23.10	23.10	12.60	23.10	33.60	46.20	52.50
23.5	0.51	10.50	10.50	10.50	21.00	21.00	10.50	21.00	31.50	44.10	50.40
23.1	0.52	8.40	8.40	8.40	18.90	18.90	8.40	18.90	29.40	42.00	48.30
22.6	0.53	6.30	6.30	6.30	16.80	16.80	6.30	16.80	27.30	39.90	46.20
22.2	0.54	4.20	4.20	4.20	14.70	14.70	4.20	14.70	25.20	37.80	44.10
21.8	0.55				12.60	12.60		12.60	23.10	35.70	42.00
21.4	0.56				10.50	10.50		10.50	21.00	33.60	39.90
21.1	0.57				8.40	8.40		8.40	18.90	31.50	37.80
20.7	0.58				6.30	6.30		6.30	16.80	29.40	35.70
20.3	0.59				4.20	4.20		4.20	14.70	27.30	33.60
20.0	0.60								12.60	25.20	31.50
19.7	0.61								10.50	23.10	29.40
19.4	0.62								8.40	21.00	27.30
19.0	0.63								6.30	18.90	25.20
18.8	0.64									16.80	23.10
18.5	0.65									14.70	21.00
18.2	0.66									12.60	18.90
17.9	0.67									10.50	16.80
17.6	0.68									8.40	14.70
17.4	0.69									6.30	12.60
17.1	0.70										10.50
16.9	0.71										8.40
16.7	0.72										6.30

Notes:

1. Certification required by manufacturer to latest released AHRI Standard 550/590
2. Chiller efficiencies do not include KW of supply air fans,
Chilled water pump, condensing water pump, tower fans or circulating pumps.
3. Required AHRI range of rating conditions - chilled water circuit 44F chilled water temp, flow rate 2.4 gpm/ton
Water cooled - tower temp 85F, flow 3.0 gpm per ton
4. Special class/size not AHRI certified must have manufacturer verified specifications at AHRI conditions
& approved by Gulf Power HVAC specialist or contractor representative
5. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Water Cooled Chillers Path B</i>											
KW Reduction Based on ASHRAE 90.1 National Energy Code Minimum Efficiency Standards											
		Water Cooled Centrifugal					Water Cooled Positive Displacement				
		Tons ≥ 600	400 ≤ Tons < 600	300 ≤ Tons < 400	150 ≤ Tons < 300	Tons < 150	Tons ≥ 600	300 ≤ Tons < 600	150 ≤ Tons < 300	75 ≤ Tons < 150	Tons < 75
Required IPLV ==>		≤ 0.380	≤ 0.380	≤ 0.39	≤ 0.400	≤ 0.440	≤ 0.380	≤ 0.410	≤ 0.44	≤ 0.49	≤ 0.500
Chiller Efficiency EER	KW/TON	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton	Incentive \$/Ton
26.7	0.45	28.35	28.35	30.45	38.85	51.45	28.35	36.75	48.30	63.00	69.30
26.1	0.46	26.25	26.25	28.35	36.75	49.35	26.25	34.65	46.20	60.90	67.20
25.5	0.47	24.15	24.15	26.25	34.65	47.25	24.15	32.55	44.10	58.80	65.10
25.0	0.48	22.05	22.05	24.15	32.55	45.15	22.05	30.45	42.00	56.70	63.00
24.5	0.49	19.95	19.95	22.05	30.45	43.05	19.95	28.35	39.90	54.60	60.90
24.0	0.50	17.85	17.85	19.95	28.35	40.95	17.85	26.25	37.80	52.50	58.80
23.5	0.51	15.75	15.75	17.85	26.25	38.85	15.75	24.15	35.70	50.40	56.70
23.1	0.52	13.65	13.65	15.75	24.15	36.75	13.65	22.05	33.60	48.30	54.60
22.6	0.53	11.55	11.55	13.65	22.05	34.65	11.55	19.95	31.50	46.20	52.50
22.2	0.54	9.45	9.45	11.55	19.95	32.55	9.45	17.85	29.40	44.10	50.40
21.8	0.55	7.35	7.35	9.45	17.85	30.45	7.35	15.75	27.30	42.00	48.30
21.4	0.56	5.25	5.25	7.35	15.75	28.35	5.25	13.65	25.20	39.90	46.20
21.1	0.57			5.25	13.65	26.25		11.55	23.10	37.80	44.10
20.7	0.58				11.55	24.15		9.45	21.00	35.70	42.00
20.3	0.59				9.45	22.05		7.35	18.90	33.60	39.90
20.0	0.60				7.35	19.95		5.25	16.80	31.50	37.80
19.7	0.61				5.25	17.85			14.70	29.40	35.70
19.4	0.62					15.75			12.60	27.30	33.60
19.0	0.63					13.65			10.50	25.20	31.50
18.8	0.64					11.55			8.40	23.10	29.40
18.5	0.65					9.45			6.30	21.00	27.30
18.2	0.66					7.35				18.90	25.20
17.9	0.67					5.25				16.80	23.10
17.6	0.68									14.70	21.00
17.4	0.69									12.60	18.90
17.1	0.70									10.50	16.80
16.9	0.71									8.40	14.70
16.7	0.72									6.30	12.60
16.4	0.73										10.50
16.2	0.74										8.40
16.0	0.75										6.30

Notes:

1. Certification required by manufacturer to latest released AHRI Standard 550/590
2. Chiller efficiencies do not include KW of supply air fans,
Chilled water pump, condensing water pump, tower fans or circulating pumps.
3. Required AHRI range of rating conditions - chilled water circuit 44F chilled water temp, flow rate 2.4 gpm/ton
Water cooled - tower temp 85F, flow 3.0 gpm per ton
4. Special class/size not AHRI certified must have manufacturer verified specifications at ARI conditions
& approved by Gulf Power HVAC specialist or contractor representative
5. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

DX Incentive Tables

<i>Gulf Power Incentives Dx Air Conditioners & Condensing Units - Air Cooled - Electric Resistance Heating or No Heating</i>								
Dx Unitary	AHRI 340/360				AHRI 240/210	AHRI 240/210		AHRI 365
	Split System & Single Package				Split System & Single Package	Space Constrained, Air Cooled	Small Duct, High Velocity, Air Cooled	Condensing Units
	Cap Tons Cap MBtuh	Tons ≥ 63.33 MBtuh ≥ 760	20 ≤ Tonnage < 63.33 240 ≤ MBtuh < 760	11.25 ≤ Tonnage < 20 135 ≤ MBtuh < 240	5.42 ≤ Tonnage < 11.25 65 ≤ MBtuh < 135	Tonnage < 5.42 MBtuh < 65	Tonnage ≤ 2.5 MBtuh ≤ 30	Tonnage < 5.42 MBtuh < 65
Eff (\$EER)	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	7.09	6.59	5.13	4.88	3.08	5.20	4.79	5.83
16.0	6.50	5.99	4.55	4.28	2.38	4.48	4.07	5.24
15.0	5.83	5.33	3.89	3.62	1.55	3.67	3.26	4.57
14.9	5.76	5.27	3.82	3.55	1.48	3.58	3.17	4.50
14.8	5.69	5.18	3.73	3.47	1.37	3.49	3.08	4.43
14.7	5.62	5.13	3.67	3.40	1.30	3.40	2.99	4.36
14.6	5.54	5.04	3.58	3.33	1.19	3.31	2.90	4.28
14.5	5.45	4.97	3.51	3.24	1.10	3.22	2.79	4.19
14.4	5.38	4.90	3.44	3.19	1.03	3.13	2.72	4.14
14.3	5.31	4.81	3.37	3.10	0.92	3.04	2.63	4.05
14.2	5.24	4.73	3.28	3.02		2.93	2.52	3.98
14.1	5.15	4.66	3.20	2.93		2.84	2.43	3.89
14.0	5.08	4.57	3.11	2.86		2.74	2.32	3.82
13.9	4.99	4.50	3.04	2.77		2.65	2.23	3.73
13.8	4.90	4.41	2.95	2.68		2.54	2.11	3.64
13.7	4.82	4.32	2.86	2.61		2.43	2.02	3.56
13.6	4.73	4.25	2.79	2.52		2.34	1.93	3.47
13.5	4.64	4.14	2.70	2.43		2.21	1.80	3.38
13.4	4.55	4.05	2.59	2.34		2.11	1.69	3.29
13.3	4.46	3.98	2.52	2.27		2.02	1.60	3.20
13.2	4.37	3.89	2.43	2.16		1.89	1.48	3.11
13.1	4.28	3.78	2.34	2.07		1.78	1.37	3.02
13.0	4.19	3.69	2.23	1.98		1.67	1.26	2.93
12.9	4.10	3.60	2.14	1.89		1.55	1.13	2.84
12.8	4.00	3.49	2.03	1.78		1.42	1.01	2.74
12.7	3.89	3.40	1.94	1.69		1.31		2.65
12.6	3.80	3.31	1.85	1.60		1.21		2.54
12.5	3.69	3.20	1.75	1.49		1.06		2.45
12.4	3.58	3.10	1.64	1.39				2.34
12.3	3.47	2.99	1.53	1.28				2.23
12.2	3.38	2.88	1.42	1.17				2.12
12.1	3.28	2.77	1.31	1.06				2.02
12.0	3.17	2.66	1.21	0.95				1.91
11.9	3.06	2.56	1.10					1.80
11.8	2.93	2.45	0.99					1.67
11.7	2.81	2.32						1.57
11.6	2.72	2.21						1.46
11.5	2.59	2.09						1.33
11.4	2.45	1.96						1.21
11.3	2.34	1.84						1.08
11.2	2.21	1.73						0.95
11.1	2.09	1.58						0.83
11.0	1.94	1.46						0.68
10.9	1.82	1.31						
10.8	1.67	1.19						
10.7	1.55	1.06						
10.6	1.40							
10.5	1.26							
10.4	1.12							

- Notes
1. One Ton = 12 MBtuh
 2. Must be AHRI certified where certification is available (250 MBtuh or less).
 3. Special class units not AHRI certified must be approved by Gulf Power HVAC specialist or contractor representative
 4. All (\$EER's in this table include condensing KW.
 5. All (\$EER's on this table include supply fans except for condensing units(AHRI 365)
 6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
 7. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Dx Air Conditioners & Condensing Units - Air Cooled - Non-Electric Resistance Heating</i>						
Dx Unitary	AHRI 340/360				AHRI 240/210	AHRI 365
	Split System & Single Package				Split System & Single Package	Condensing Units
	Cap Tons Cap MBtuh	Tons ≥ 63.33 MBtuh ≥ 760	20 ≤ Tons < 63.33 240 ≤ MBtuh < 760	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65
Eff (\$)EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	7.43	6.91	5.40	5.13	3.08	5.83
16.0	6.84	6.34	4.82	4.55	2.38	5.24
15.0	6.17	5.67	4.16	3.89	1.55	4.57
14.9	6.10	5.60	4.09	3.82	1.48	4.50
14.8	6.03	5.51	4.00	3.73	1.37	4.43
14.7	5.96	5.45	3.94	3.67	1.30	4.36
14.6	5.89	5.36	3.85	3.58	1.19	4.28
14.5	5.80	5.29	3.78	3.51	1.10	4.19
14.4	5.74	5.22	3.71	3.44	1.03	4.14
14.3	5.65	5.15	3.64	3.37	0.92	4.05
14.2	5.58	5.06	3.55	3.28		3.98
14.1	5.49	4.99	3.47	3.20		3.89
14.0	5.42	4.90	3.38	3.11		3.82
13.9	5.35	4.82	3.31	3.04		3.73
13.8	5.24	4.73	3.22	2.95		3.64
13.7	5.17	4.64	3.13	2.86		3.56
13.6	5.08	4.57	3.06	2.79		3.47
13.5	4.99	4.48	2.97	2.70		3.38
13.4	4.90	4.37	2.86	2.59		3.29
13.3	4.82	4.30	2.79	2.52		3.20
13.2	4.72	4.21	2.70	2.43		3.11
13.1	4.63	4.12	2.61	2.34		3.02
13.0	4.54	4.01	2.50	2.23		2.93
12.9	4.45	3.92	2.41	2.14		2.84
12.8	4.34	3.82	2.30	2.03		2.74
12.7	4.25	3.73	2.21	1.94		2.65
12.6	4.16	3.64	2.12	1.85		2.54
12.5	4.05	3.53	2.02	1.75		2.45
12.4	3.94	3.42	1.91	1.64		2.34
12.3	3.83	3.31	1.80	1.53		2.23
12.2	3.73	3.20	1.69	1.42		2.12
12.1	3.62	3.10	1.58	1.31		2.02
12.0	3.51	2.99	1.48	1.21		1.91
11.9	3.40	2.88	1.37	1.10		1.80
11.8	3.28	2.77	1.26	0.99		1.67
11.7	3.17	2.65	1.13			1.57
11.6	3.06	2.54	1.03			1.46
11.5	2.93	2.43				1.33
11.4	2.81	2.29				1.21
11.3	2.68	2.16				1.08
11.2	2.56	2.05				0.95
11.1	2.43	1.91				0.83
11.0	2.30	1.78				0.68
10.9	2.16	1.66				
10.8	2.03	1.51				
10.7	1.89	1.39				
10.6	1.75	1.24				
10.5	1.60	1.08				
10.4	1.46					
10.3	1.31					
10.2	1.17					

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by Gulf Power HVAC specialist or contractor representative
4. All (\$)EER's in this table include condensing Kw.
5. All (\$)EER's on this table include supply fans except for condensing units(AHRI 365)
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Dv Air Conditioners & Condensing Units - Water Cooled - Electric Resistance Heating or No Heating</i>					AHRI 210/240	AHRI 365
					Split System & Single Package	Condensing Units
Cap Tons Cap MBtuh	Tons ≥ 63.3 MBtuh ≥ 760	63.3 > Tons ≥ 20 760 > MBtuh ≥ 240	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65	Tons ≥ 11.25 MBtuh ≥ 135
Eff EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	3.71	3.49	3.38	3.82	3.82	2.45
16.9	3.65	3.44	3.33	3.76	3.76	2.39
16.8	3.60	3.38	3.28	3.71	3.71	2.34
16.7	3.53	3.31	3.22	3.64	3.64	2.27
16.6	3.47	3.26	3.17	3.58	3.58	2.21
16.5	3.42	3.20	3.11	3.53	3.53	2.16
16.4	3.35	3.15	3.04	3.46	3.46	2.09
16.3	3.29	3.10	2.99	3.42	3.42	2.03
16.2	3.24	3.02	2.92	3.35	3.35	1.98
16.1	3.19	2.97	2.86	3.29	3.29	1.93
16.0	3.11	2.90	2.81	3.22	3.22	1.85
15.9	3.04	2.84	2.74	3.15	3.15	1.78
15.8	2.99	2.79	2.68	3.10	3.10	1.73
15.7	2.93	2.72	2.61	3.04	3.04	1.67
15.6	2.86	2.65	2.56	2.97	2.97	1.60
15.5	2.79	2.59	2.48	2.90	2.90	1.53
15.4	2.74	2.52	2.41	2.84	2.84	1.46
15.3	2.66	2.45	2.34	2.77	2.77	1.40
15.2	2.59	2.38	2.29	2.70	2.70	1.33
15.1	2.52	2.30	2.20	2.63	2.63	1.26
15.0	2.45	2.23	2.14	2.56	2.56	1.19
14.9	2.38	2.18	2.07	2.48	2.48	1.12
14.8	2.30	2.09	1.98	2.41	2.41	1.04
14.7	2.23	2.02	1.93	2.34	2.34	0.97
14.6	2.16	1.94	1.84	2.27	2.27	0.90
14.5	2.07	1.87	1.76	2.18	2.18	0.81
14.4	2.02	1.80	1.69	2.12	2.12	0.74
14.3	1.93	1.71	1.62	2.03	2.03	
14.2	1.85	1.64	1.53	1.96	1.96	
14.1	1.76	1.57	1.46	1.87	1.87	
14.0	1.69	1.48	1.37	1.80	1.80	
13.9	1.60	1.40	1.30	1.71	1.71	
13.8	1.51	1.30	1.21	1.62	1.62	
13.7	1.44	1.22	1.12	1.55	1.55	
13.6	1.35	1.15	1.04	1.46	1.46	
13.5	1.26	1.04	0.95	1.37	1.37	
13.4	1.17	0.95	0.85	1.28	1.28	
13.3	1.10	0.88		1.21	1.21	
13.2	0.99			1.10	1.10	
13.1	0.90			1.01	1.01	
13.0				0.92	0.92	
12.9				0.83	0.83	
12.8						
12.7						

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by Gulf Power HVAC specialist or contractor representative.
4. All (S)EER's in this Table include supply fans except for condensing units(AHRI 365)
5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Water cooled - tower temp 85F, flow 3.0 gpm per ton
8. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Dx Air Conditioners & Condensing Units - Water Cooled - Non-Electric Resistance Heating</i>						
AHRI 340/360					AHRI 210/240	AHRI 365
Split System & Single Package					Split System & Single Package	Condensing Units
Cap Tons	Tons ≥ 63.3	63.3 > Tons ≥ 20	11.25 ≤ Tons < 20	.42 ≤ Tons < 11.2	Tons < 5.42	Tons ≥ 11.25
Cap MBtuh	MBtuh ≥ 760	760 > MBtuh ≥ 240	135 ≤ MBtuh < 240	65 ≤ MBtuh < 135	MBtuh < 65	MBtuh ≥ 135
Eff EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	3.92	3.71	3.60	4.03	3.82	2.45
16.9	3.87	3.65	3.55	3.98	3.76	2.39
16.8	3.82	3.60	3.49	3.92	3.71	2.34
16.7	3.74	3.53	3.42	3.85	3.64	2.27
16.6	3.69	3.47	3.37	3.80	3.58	2.21
16.5	3.64	3.42	3.31	3.76	3.53	2.16
16.4	3.58	3.35	3.26	3.69	3.46	2.09
16.3	3.53	3.29	3.20	3.64	3.42	2.03
16.2	3.46	3.24	3.13	3.56	3.35	1.98
16.1	3.40	3.19	3.08	3.51	3.29	1.93
16.0	3.33	3.11	3.01	3.44	3.22	1.85
15.9	3.28	3.04	2.93	3.38	3.15	1.78
15.8	3.22	2.99	2.90	3.33	3.10	1.73
15.7	3.15	2.93	2.83	3.26	3.04	1.67
15.6	3.08	2.86	2.75	3.19	2.97	1.60
15.5	3.01	2.79	2.68	3.13	2.90	1.53
15.4	2.95	2.74	2.63	3.06	2.84	1.46
15.3	2.88	2.66	2.56	2.99	2.77	1.40
15.2	2.81	2.59	2.48	2.93	2.70	1.33
15.1	2.74	2.52	2.41	2.84	2.63	1.26
15.0	2.66	2.45	2.34	2.77	2.56	1.19
14.9	2.61	2.38	2.27	2.72	2.48	1.12
14.8	2.52	2.30	2.20	2.63	2.41	1.04
14.7	2.45	2.23	2.12	2.57	2.34	0.97
14.6	2.38	2.16	2.05	2.48	2.27	0.90
14.5	2.29	2.07	1.96	2.41	2.18	0.81
14.4	2.23	2.02	1.91	2.34	2.12	0.74
14.3	2.14	1.93	1.82	2.27	2.03	
14.2	2.07	1.85	1.75	2.18	1.96	
14.1	1.98	1.76	1.66	2.11	1.87	
14.0	1.91	1.69	1.58	2.02	1.80	
13.9	1.84	1.60	1.49	1.94	1.71	
13.8	1.73	1.51	1.40	1.85	1.62	
13.7	1.66	1.44	1.33	1.76	1.55	
13.6	1.57	1.35	1.24	1.69	1.46	
13.5	1.48	1.26	1.15	1.60	1.37	
13.4	1.39	1.17	1.06	1.49	1.28	
13.3	1.31	1.10	0.99	1.42	1.21	
13.2	1.21	0.99	0.88	1.33	1.10	
13.1	1.12	0.90		1.24	1.01	
13.0	1.03			1.13	0.92	
12.9	0.94			1.04	0.83	
12.8	0.83			0.94		
12.7				0.85		

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by Gulf Power HVAC specialist or contractor representative.
4. All (S)EER's in this Table include supply fans except for condensing units(AHRI 365)
5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Water cooled - tower temp 85F, flow 3.0 gpm per ton
8. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Dx Air Conditioners & Condensing Units - Evaporative Cooled - Electric Resistance Heating or No Heating</i>					AHRI 210/240	AHRI 365
					Split System & Single Package	Condensing Units
Cap Tons Cap MBtuh	Tons ≥ 63.3 MBtuh ≥ 760	63.3 > Tons ≥ 20 760 > MBtuh ≥ 240	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65	Tons ≥ 11.25 MBtuh ≥ 135
Eff EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	4.27	4.03	3.92	3.82	3.82	2.45
16.9	4.21	3.98	3.87	3.76	3.76	2.39
16.8	4.16	3.92	3.82	3.71	3.71	2.34
16.7	4.09	3.85	3.74	3.64	3.64	2.27
16.6	4.03	3.80	3.69	3.58	3.58	2.21
16.5	3.98	3.76	3.64	3.53	3.53	2.16
16.4	3.92	3.69	3.58	3.46	3.46	2.09
16.3	3.87	3.64	3.53	3.42	3.42	2.03
16.2	3.80	3.56	3.46	3.35	3.35	1.98
16.1	3.74	3.51	3.40	3.29	3.29	1.93
16.0	3.67	3.44	3.33	3.22	3.22	1.85
15.9	3.62	3.38	3.28	3.15	3.15	1.78
15.8	3.56	3.33	3.22	3.10	3.10	1.73
15.7	3.49	3.26	3.15	3.04	3.04	1.67
15.6	3.42	3.19	3.08	2.97	2.97	1.60
15.5	3.35	3.13	3.01	2.90	2.90	1.53
15.4	3.29	3.06	2.95	2.84	2.84	1.46
15.3	3.22	2.99	2.88	2.77	2.77	1.40
15.2	3.15	2.93	2.81	2.70	2.70	1.33
15.1	3.08	2.84	2.74	2.63	2.63	1.26
15.0	3.01	2.77	2.66	2.56	2.56	1.19
14.9	2.95	2.72	2.61	2.48	2.48	1.12
14.8	2.86	2.63	2.52	2.41	2.41	1.04
14.7	2.79	2.57	2.45	2.34	2.34	0.97
14.6	2.72	2.48	2.38	2.27	2.27	0.90
14.5	2.63	2.41	2.29	2.18	2.18	0.81
14.4	2.57	2.34	2.23	2.12	2.12	0.74
14.3	2.48	2.27	2.14	2.03	2.03	
14.2	2.41	2.18	2.07	1.96	1.96	
14.1	2.32	2.11	1.98	1.87	1.87	
14.0	2.25	2.02	1.91	1.80	1.80	
13.9	2.18	1.94	1.84	1.71	1.71	
13.8	2.07	1.85	1.73	1.62	1.62	
13.7	2.00	1.76	1.66	1.55	1.55	
13.6	1.91	1.69	1.57	1.46	1.46	
13.5	1.82	1.60	1.48	1.37	1.37	
13.4	1.73	1.49	1.39	1.28	1.28	
13.3	1.66	1.42	1.31	1.21	1.21	
13.2	1.55	1.33	1.21	1.10	1.10	
13.1	1.46	1.24	1.12	1.01	1.01	
13.0	1.37	1.13	1.03	0.92	0.92	
12.9	1.28	1.04	0.94	0.83	0.83	
12.8	1.17	0.94	0.83			
12.7	1.08	0.85				
12.6	0.99					
12.5	0.88					

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by Gulf Power HVAC specialist or contractor representative.
4. All (S)EER's in this Table include supply fans except for condensing units(AHRI 365)
5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Water cooled - tower temp 85F, flow 3.0 gpm per ton
8. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Dx Air Conditioners & Condensing Units - Evaporative Cooled - Non-Electric Resistance Heating</i>					
					AHRI 210/240
					Split System & Single Package
Cap Tons Cap MBtuh	Tons ≥ 63.3 MBtuh ≥ 760	63.3 > Tons ≥ 20 760 > MBtuh ≥ 240	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65
Eff EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	4.50	4.27	4.14	4.03	3.82
16.9	4.45	4.21	4.09	3.98	3.76
16.8	4.39	4.16	4.03	3.92	3.71
16.7	4.32	4.09	3.98	3.85	3.64
16.6	4.27	4.03	3.92	3.80	3.58
16.5	4.23	3.98	3.87	3.76	3.53
16.4	4.16	3.92	3.80	3.69	3.46
16.3	4.10	3.87	3.74	3.64	3.42
16.2	4.03	3.80	3.67	3.56	3.35
16.1	3.98	3.74	3.64	3.51	3.29
16.0	3.91	3.67	3.56	3.44	3.22
15.9	3.85	3.62	3.49	3.38	3.15
15.8	3.80	3.56	3.44	3.33	3.10
15.7	3.73	3.49	3.37	3.26	3.04
15.6	3.65	3.42	3.31	3.19	2.97
15.5	3.60	3.35	3.24	3.13	2.90
15.4	3.53	3.29	3.17	3.06	2.84
15.3	3.46	3.22	3.11	2.99	2.77
15.2	3.40	3.15	3.04	2.93	2.70
15.1	3.31	3.08	2.95	2.84	2.63
15.0	3.24	3.01	2.90	2.77	2.56
14.9	3.19	2.95	2.83	2.72	2.48
14.8	3.10	2.86	2.75	2.63	2.41
14.7	3.04	2.79	2.68	2.57	2.34
14.6	2.95	2.72	2.59	2.48	2.27
14.5	2.88	2.63	2.52	2.41	2.18
14.4	2.81	2.57	2.45	2.34	2.12
14.3	2.74	2.48	2.38	2.27	2.03
14.2	2.65	2.41	2.29	2.18	1.96
14.1	2.57	2.32	2.21	2.11	1.87
14.0	2.48	2.25	2.14	2.02	1.80
13.9	2.41	2.18	2.05	1.94	1.71
13.8	2.32	2.07	1.96	1.85	1.62
13.7	2.23	2.00	1.87	1.76	1.55
13.6	2.16	1.91	1.80	1.69	1.46
13.5	2.05	1.82	1.71	1.60	1.37
13.4	1.96	1.73	1.62	1.49	1.28
13.3	1.89	1.66	1.53	1.42	1.21
13.2	1.80	1.55	1.44	1.33	1.10
13.1	1.69	1.46	1.35	1.24	1.01
13.0	1.60	1.37	1.26	1.13	0.92
12.9	1.51	1.28	1.15	1.04	0.83
12.8	1.40	1.17	1.06	0.94	
12.7	1.31	1.08	0.95	0.85	
12.6	1.22	0.99	0.86		
12.5	1.12	0.88			
12.4	1.01				
12.3	0.90				

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by Gulf Power HVAC specialist or contractor representative.
4. All (S)EER's in this Table include supply fans except for condensing units(AHRI 365)
5. AHRI return air temp is 80F dry bulb and 67F wet bulb.
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Water cooled - tower temp 85F, flow 3.0 gpm per ton
8. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Dx Heat Pump - Air Cooled - Cooling Mode - Electric Resistance Heating or No Heating</i>								
AHRI 360/340				AHRI 240/210		AHRI 240/210		AHRI 365
Dx Unitary		Split System and Single Package			Split System		Single Package	Condensing Unit
Cap. Tonnage Cap. MBtu/h	202 Tonnage 2402 MBtu/h	11.255 Tonnage < 20 355 MBtu/h < 240	.425 Tonnage < 11.2 655 MBtu/h < 135	Tonnage < 5.42 MBtu/h < 65	Tonnage < 5.42 MBtu/h < 65	Tonnage ≤ 2.5 MBtu/h ≤ 30	Tonnage < 5.42 MBtu/h < 65	Tonnage ≥ 11.25 MBtu/h ≥ 135
Eff (S)EER(2)	Incentive \$/MBtu/h	Incentive \$/MBtu/h	Incentive \$/MBtu/h	Incentive \$/MBtu/h	Incentive \$/MBtu/h	Incentive \$/MBtu/h	Incentive \$/MBtu/h	Incentive \$/MBtu/h
16.0	6.84	5.09	4.55	1.46	2.38	4.48	4.07	5.24
15.9	6.79	5.02	4.48	1.37	2.29	4.41	3.98	5.17
15.8	6.73	4.97	4.43	1.30	2.21	4.34	3.92	5.11
15.7	6.66	4.91	4.36	1.22	2.14	4.25	3.83	5.06
15.6	6.59	4.84	4.30	1.13	2.05	4.18	3.76	4.99
15.5	6.52	4.77	4.23	1.06	1.98	4.09	3.67	4.91
15.4	6.46	4.72	4.16	0.97	1.89	4.01	3.60	4.86
15.3	6.39	4.64	4.09	0.90	1.82	3.92	3.51	4.79
15.2	6.32	4.57	4.03		1.73	3.85	3.44	4.72
15.1	6.25	4.50	3.94		1.64	3.74	3.33	4.64
15.0	6.17	4.43	3.89		1.55	3.67	3.26	4.57
14.9	6.10	4.36	3.82		1.48	3.58	3.17	4.50
14.8	6.03	4.28	3.73		1.37	3.49	3.08	4.43
14.7	5.96	4.21	3.67		1.30	3.40	2.99	4.36
14.6	5.89	4.14	3.58		1.19	3.31	2.90	4.28
14.5	5.80	4.05	3.51		1.10	3.22	2.79	4.19
14.4	5.74	4.00	3.44		1.03	3.13	2.72	4.14
14.3	5.65	3.91	3.37		0.92	3.04	2.63	4.05
14.2	5.58	3.83	3.28			2.93	2.52	3.98
14.1	5.49	3.74	3.20			2.84	2.43	3.89
14.0	5.42	3.67	3.11			2.74	2.32	3.82
13.9	5.35	3.58	3.04			2.65	2.23	3.73
13.8	5.24	3.49	2.95			2.54	2.11	3.64
13.7	5.17	3.42	2.86			2.43	2.02	3.56
13.6	5.08	3.33	2.79			2.34	1.93	3.48
13.5	4.99	3.24	2.70			2.21	1.80	3.39
13.4	4.90	3.15	2.59			2.11	1.69	3.29
13.3	4.82	3.06	2.52			2.02	1.60	3.21
13.2	4.72	2.97	2.43			1.89	1.48	3.12
13.1	4.63	2.88	2.34			1.78	1.37	3.03
13.0	4.54	2.79	2.23			1.67	1.26	2.93
12.9	4.45	2.70	2.14			1.55	1.13	2.84
12.8	4.34	2.59	2.03			1.42	1.01	2.73
12.7	4.25	2.50	1.94			1.31		2.64
12.6	4.16	2.39	1.85			1.21		2.55
12.5	4.05	2.30	1.75			1.06		2.44
12.4	3.94	2.20	1.64					2.33
12.3	3.83	2.09	1.53					2.23
12.2	3.73	1.98	1.42					2.12
12.1	3.62	1.87	1.31					2.01
12.0	3.51	1.76	1.21					1.91
11.9	3.40	1.66	1.10					1.80
11.8	3.28	1.53	0.99					1.68
11.7	3.17	1.42						1.56
11.6	3.06	1.31						1.45
11.5	2.93	1.19						1.33
11.4	2.81	1.06						1.20
11.3	2.68	0.94						1.08
11.2	2.56							0.96
11.1	2.43							0.82
11.0	2.30							0.69
10.9	2.16							
10.8	2.03							
10.7	1.89							
10.6	1.75							
10.5	1.60							
10.4	1.46							
10.3	1.31							
10.2	1.17							

- Notes:
1. One Ton - 12 MBtu/h
 2. Must be AHRI certified where certification is available (250 MBtu/h or less).
 3. Special class units not AHRI certified must be approved by Gulf Power HVAC specialist or contractor representative.
 4. All (S)EER's in this table include condensing KW.
 5. All (S)EER's on this table include supply fans except for condensing units (AHRI 365).
 6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
 7. Efficiency or higher than maximum table rating will be computed by Gulf Power.
 8. SS: Split System; SP: Single Package

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Dx Heat Pump - Air Cooled - Cooling Mode - Non-Electric Resistance Heating</i>								
Dx Unitary	AHRI 248/248			AHRI 248/248	AHRI 248/248	AHRI 248/248		AHRI 365
	Split System and Single Package			Split System	Single Package	Unrestricted, Air Cooled, SS SP	High Velocity, Air Cooled	Condensing Unit
	Cap. Tonnage Cap. MBtuh	20 ≤ Tonnage 248 ≤ MBtuh	11.25 ≤ Tonnage < 20 135 ≤ MBtuh < 248	.42 ≤ Tonnage < 11.2 ES ≤ MBtuh < 135	Tonnage < 5.42 MBtuh < ES	Tonnage < 5.42 MBtuh < ES	Tonnage ≤ 2.5 MBtuh ≤ 30	Tonnage < 5.42 MBtuh < ES
Eff. EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	7.79	5.97	5.40	2.17	3.08	5.20	4.78	5.83
16.0	7.21	5.39	4.82	1.45	2.37	4.48	4.07	5.24
15.9	7.14	5.32	4.75	1.37	2.29	4.40	3.98	5.17
15.8	7.09	5.27	4.70	1.30	2.22	4.34	3.92	5.12
15.7	7.02	5.20	4.63	1.22	2.14	4.25	3.84	5.05
15.6	6.95	5.13	4.56	1.14	2.06	4.17	3.76	4.99
15.5	6.89	5.07	4.50	1.06	1.98	4.09	3.68	4.92
15.4	6.82	5.00	4.43	0.98	1.89	4.01	3.59	4.85
15.3	6.75	4.93	4.36	0.90	1.81	3.93	3.51	4.79
15.2	6.69	4.87	4.30		1.73	3.85	3.43	4.72
15.1	6.61	4.79	4.22		1.63	3.75	3.33	4.64
15.0	6.54	4.72	4.15		1.55	3.67	3.25	4.57
14.9	6.47	4.65	4.08		1.47	3.59	3.17	4.51
14.8	6.39	4.57	4.00		1.37	3.49	3.07	4.43
14.7	6.33	4.51	3.94		1.29	3.41	2.99	4.36
14.6	6.25	4.43	3.86		1.20	3.31	2.89	4.28
14.5	6.17	4.35	3.78		1.10	3.21	2.80	4.20
14.4	6.10	4.28	3.71		1.02	3.13	2.72	4.13
14.3	6.02	4.20	3.63		0.92	3.04	2.62	4.05
14.2	5.94	4.12	3.55			2.94	2.52	3.97
14.1	5.86	4.04	3.47			2.84	2.42	3.89
14.0	5.78	3.96	3.39			2.74	2.33	3.81
13.9	5.70	3.88	3.31			2.64	2.23	3.73
13.8	5.61	3.79	3.22			2.53	2.11	3.64
13.7	5.52	3.71	3.14			2.43	2.02	3.56
13.6	5.44	3.63	3.06			2.34	1.92	3.48
13.5	5.35	3.53	2.96			2.22	1.81	3.39
13.4	5.26	3.44	2.87			2.11	1.69	3.29
13.3	5.18	3.36	2.79			2.01	1.59	3.21
13.2	5.08	3.27	2.70			1.90	1.48	3.12
13.1	4.99	3.17	2.60			1.78	1.37	3.03
13.0	4.90	3.08	2.51			1.67	1.25	2.93
12.9	4.80	2.98	2.42			1.56	1.14	2.84
12.8	4.70	2.88	2.31			1.43	1.01	2.73
12.7	4.60	2.78	2.22			1.31		2.64
12.6	4.51	2.69	2.12			1.20		2.55
12.5	4.40	2.58	2.02			1.07		2.44
12.4	4.30	2.48	1.91					2.33
12.3	4.19	2.37	1.80					2.23
12.2	4.08	2.26	1.70					2.12
12.1	3.98	2.16	1.59					2.01
12.0	3.87	2.05	1.48					1.91
11.9	3.76	1.94	1.37					1.80
11.8	3.64	1.82	1.25					1.68
11.7	3.52	1.70	1.13					1.56
11.6	3.42	1.60	1.03					1.45
11.5	3.30	1.48						1.33
11.4	3.16	1.34						1.20
11.3	3.04	1.22						1.08
11.2	2.92	1.10						0.96
11.1	2.79	0.97						0.82
11.0	2.66							0.69
10.9	2.52							
10.8	2.39							
10.7	2.26							
10.6	2.11							
10.5	1.96							
10.4	1.82							
10.3	1.67							
10.2	1.52							
10.1	1.36							
10.0	1.20							

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by Gulf Power HVAC Specialist or contractor representative
4. All (S)EER's in this table include condensing KW.
5. All (S)EER's on this table include supply fans except for condensing units (AHRI 365)
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Efficiency higher than maximum table rating will be computed by Gulf Power
8. SS: Split System; SP: Single Package

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives Dx Heat Pump - Air Cooled - Cooling Mode - Non-Electric Resistance Heating</i>								
Dx Unitary	AHRI 350/340			AHRI 240/210		AHRI 240/210		AHRI 365
	Split System and Single Package			Split System		Single Package	Condensing Unit	Condensing Unit
	200 Tons 2400 MBtuh	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	.42 ≤ Tons < 11.2 ES MBtuh < 135	Tons < 5.42 MBtuh < 65	Tons < 5.42 MBtuh < 65	Tons ≤ 2.5 MBtuh ≤ 30	Tons < 5.42 MBtuh < 65	Tons ≥ 11.25 MBtuh ≥ 135
Eff EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
17.0	7.79	5.98	5.40	2.16	3.08	5.20	4.79	5.83
16.0	7.20	5.38	4.82	1.46	2.38	4.48	4.07	5.24
15.9	7.15	5.33	4.75	1.37	2.29	4.41	3.98	5.17
15.8	7.09	5.27	4.70	1.30	2.21	4.34	3.92	5.11
15.7	7.02	5.20	4.63	1.22	2.14	4.25	3.83	5.06
15.6	6.95	5.13	4.55	1.13	2.05	4.18	3.76	4.99
15.5	6.89	5.06	4.50	1.06	1.98	4.09	3.67	4.91
15.4	6.82	5.00	4.43	0.97	1.89	4.01	3.60	4.86
15.3	6.75	4.93	4.36	0.90	1.82	3.92	3.51	4.79
15.2	6.68	4.86	4.30		1.73	3.85	3.44	4.72
15.1	6.61	4.79	4.21		1.64	3.74	3.33	4.64
15.0	6.53	4.72	4.16		1.55	3.67	3.26	4.57
14.9	6.48	4.64	4.09		1.48	3.58	3.17	4.50
14.8	6.39	4.57	4.00		1.37	3.49	3.08	4.43
14.7	6.32	4.50	3.94		1.30	3.40	2.99	4.36
14.6	6.25	4.43	3.85		1.19	3.31	2.90	4.28
14.5	6.17	4.34	3.78		1.10	3.22	2.79	4.19
14.4	6.10	4.28	3.71		1.03	3.13	2.72	4.14
14.3	6.01	4.19	3.64		0.92	3.04	2.63	4.05
14.2	5.94	4.12	3.55			2.93	2.52	3.98
14.1	5.87	4.03	3.47			2.84	2.43	3.89
14.0	5.78	3.96	3.38			2.74	2.32	3.82
13.9	5.71	3.89	3.31			2.65	2.23	3.73
13.8	5.60	3.78	3.22			2.54	2.11	3.64
13.7	5.53	3.71	3.13			2.43	2.02	3.56
13.6	5.45	3.62	3.06			2.34	1.93	3.47
13.5	5.35	3.53	2.97			2.21	1.80	3.38
13.4	5.26	3.44	2.86			2.11	1.69	3.29
13.3	5.18	3.37	2.79			2.02	1.60	3.20
13.2	5.09	3.26	2.70			1.89	1.48	3.11
13.1	4.99	3.17	2.61			1.78	1.37	3.02
13.0	4.90	3.08	2.50			1.67	1.26	2.93
12.9	4.81	2.99	2.41			1.55	1.13	2.84
12.8	4.70	2.88	2.30			1.42	1.01	2.74
12.7	4.61	2.79	2.21			1.31		2.65
12.6	4.52	2.70	2.12			1.21		2.54
12.5	4.41	2.59	2.02			1.06		2.45
12.4	4.30	2.48	1.91					2.34
12.3	4.19	2.38	1.80					2.23
12.2	4.09	2.27	1.69					2.12
12.1	3.98	2.16	1.58					2.02
12.0	3.87	2.05	1.48					1.91
11.9	3.76	1.94	1.37					1.80
11.8	3.65	1.82	1.26					1.67
11.7	3.53	1.71	1.13					1.57
11.6	3.42	1.60	1.03					1.46
11.5	3.29	1.48						1.33
11.4	3.17	1.35						1.21
11.3	3.04	1.22						1.08
11.2	2.93	1.10						0.95
11.1	2.79	0.97						0.83
11.0	2.66							0.68
10.9	2.52							
10.8	2.39							
10.7	2.25							
10.6	2.11							
10.5	1.96							
10.4	1.82							
10.3	1.67							
10.2	1.53							
10.1	1.37							
10.0	1.21							

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI certified where certification is available (250 MBtuh or less).
3. Special class units not AHRI certified must be approved by Gulf Power HVAC Specialist or contractor representative
4. All (S)EER's in this table include condensing KW.
5. All (S)EER's on this table include supply fans except for condensing units (AHRI 365)
6. Equipment rating at net capacity with return air 80F dry bulb and 67F wet bulb.
7. Efficiency higher than maximum table rating will be computed by Gulf Power
8. SS: Split System; SP: Single Package

Gulf Power Business HVAC Program Tables

<i>DX Heat Pump Unitary and Applied - Water Source</i>			
	Water to Air, Water Loop	Water to Air, Water Loop	Water to Water, Water Loop
	Water Source (86 F entering water) ISO 13256-1		Water Source (86 F entering water) ISO 13256-2
Cap	135 > MBtuh ≥ 17	MBtuh < 17	All Cap
Eff EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
20.0	4.30	5.11	7.09
19.0	3.89	4.70	6.68
18.0	3.42	4.23	6.21
17.0	2.90	3.71	5.69
16.0	2.30	3.11	5.09
15.9	2.25	3.04	5.02
15.8	2.20	2.99	4.97
15.7	2.12	2.93	4.91
15.6	2.05	2.86	4.84
15.5	1.98	2.79	4.77
15.4	1.93	2.74	4.72
15.3	1.85	2.66	4.64
15.2	1.78	2.59	4.57
15.1	1.71	2.52	4.50
15.0	1.64	2.45	4.43
14.9	1.58	2.38	4.36
14.8	1.49	2.30	4.28
14.7	1.42	2.23	4.21
14.6	1.35	2.16	4.14
14.5	1.26	2.07	4.05
14.4	1.21	2.02	4.00
14.3	1.12	1.93	3.91
14.2	1.04	1.85	3.83
14.1	0.95	1.76	3.74
14.0	0.88	1.69	3.67
13.9	0.81	1.60	3.58
13.8		1.51	3.49
13.7		1.44	3.42
13.6		1.35	3.33
13.5		1.26	3.24
13.4		1.17	3.15
13.3		1.10	3.06
13.2		0.99	2.97
13.1		0.90	2.88
13.0			2.79
12.9			2.70
12.8			2.59
12.7			2.50
12.6			2.39
12.5			2.30
12.4			2.20
12.3			2.09
12.2			1.98
12.1			1.87
12.0			1.76
11.9			1.66
11.8			1.53
11.7			1.42
11.6			1.31
11.5			1.19
11.4			1.06
11.3			0.94

Notes

1. One Ton = 12 MBtuh
2. Must be AHRI/ISO certified where certification is available (135 MBtuh or less).
3. Special class units not AHRI/ISO certified must be approved by Gulf Power HVAC specialist or contractor representative
4. All EER's on this table include supply fans kw
5. Liquid flow rate per mfr
6. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Room Packaged Terminal Air Conditioners and Heat Pumps - Air Cooled (Standard Size)</i>									
AHRI 310/380									
Cap	MBtuh ≥ 15	14 \leq MBtuh < 15	13 \leq MBtuh < 14	12 \leq MBtuh < 13	11 \leq MBtuh < 12	10 \leq MBtuh < 11	9 \leq MBtuh < 10	7 \leq MBtuh < 9	MBtuh < 7
Eff	Incentive	Incentive	Incentive	Incentive	Incentive	Incentive	Incentive	Incentive	Incentive
EER	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh	\$/MBtuh
14.0	5.42	4.90	4.41	3.96	3.53	3.11	2.74	2.38	2.02
13.9	5.35	4.82	4.34	3.89	3.46	3.04	2.65	2.29	1.94
13.8	5.24	4.73	4.25	3.78	3.35	2.95	2.56	2.20	1.85
13.7	5.17	4.64	4.16	3.71	3.28	2.86	2.48	2.11	1.76
13.6	5.08	4.57	4.09	3.62	3.19	2.79	2.39	2.03	1.69
13.5	4.99	4.48	4.00	3.53	3.10	2.70	2.30	1.94	1.60
13.4	4.90	4.37	3.89	3.44	3.01	2.59	2.21	1.85	1.49
13.3	4.82	4.30	3.82	3.37	2.93	2.52	2.14	1.76	1.42
13.2	4.72	4.21	3.73	3.26	2.83	2.43	2.03	1.67	1.33
13.1	4.63	4.12	3.64	3.17	2.74	2.34	1.94	1.58	1.24
13.0	4.54	4.01	3.53	3.08	2.65	2.23	1.85	1.49	1.13
12.9	4.45	3.92	3.44	2.99	2.56	2.14	1.76	1.39	1.04
12.8	4.34	3.82	3.33	2.88	2.45	2.03	1.66	1.30	0.94
12.7	4.25	3.73	3.24	2.79	2.36	1.94	1.57	1.19	0.85
12.6	4.16	3.64	3.15	2.70	2.27	1.85	1.48	1.10	
12.5	4.05	3.53	3.04	2.59	2.16	1.75	1.37	0.99	
12.4	3.94	3.42	2.93	2.48	2.05	1.64	1.26	0.88	
12.3	3.83	3.31	2.83	2.38	1.94	1.53	1.15		
12.2	3.73	3.20	2.72	2.27	1.84	1.42	1.04		
12.1	3.62	3.10	2.61	2.16	1.73	1.31	0.94		
12.0	3.51	2.99	2.50	2.05	1.62	1.21			
11.9	3.40	2.88	2.39	1.94	1.51	1.10			
11.8	3.28	2.77	2.29	1.82	1.39	0.99			
11.7	3.17	2.65	2.16	1.71	1.28				
11.6	3.06	2.54	2.05	1.60	1.17				
11.5	2.93	2.43	1.94	1.48	1.04				
11.4	2.81	2.29	1.80	1.35	0.92				
11.3	2.68	2.16	1.67	1.22					
11.2	2.56	2.05	1.57	1.10					
11.1	2.43	1.91	1.42	0.97					
11.0	2.30	1.78	1.30						
10.9	2.16	1.66	1.17						
10.8	2.03	1.51	1.03						
10.7	1.89	1.39							
10.6	1.75	1.24							
10.5	1.60	1.08							
10.4	1.46								
10.3	1.31								
10.2	1.17								

Notes

1. 1,000 Btuh = 1MBtuh
2. Must be AHRI certified
3. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

	<i>Single Package Vertical AC and Heat Pumps</i>		
	Single Pack Vertical AC & HP Single and Three Phase	Single Pack Vertical AC & HP Single and Three Phase	Single Pack Vertical AC & HP Single and Three Phase
Cap	135 ≤ MBtuh < 240	65 ≤ MBtuh < 135	65 < Mbtuh
Eff EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.69	3.69	2.23
12.9	3.60	3.60	2.14
12.8	3.49	3.49	2.03
12.7	3.40	3.40	1.94
12.6	3.31	3.31	1.85
12.5	3.20	3.20	1.75
12.4	3.10	3.10	1.64
12.3	2.99	2.99	1.53
12.2	2.88	2.88	1.42
12.1	2.77	2.77	1.31
12.0	2.66	2.66	1.21
11.9	2.56	2.56	1.10
11.8	2.45	2.45	0.99
11.7	2.32	2.32	
11.6	2.21	2.21	
11.5	2.09	2.09	
11.4	1.96	1.96	
11.3	1.84	1.84	
11.2	1.73	1.73	
11.1	1.58	1.58	
11.0	1.46	1.46	
10.9	1.31	1.31	
10.8	1.19	1.19	
10.7	1.06	1.06	
10.6			

Notes

1. 1,000 Btuh = 1 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX VRF Air Conditioners - Air Cooled</i>				
Dx Unitary	AHRI 1230			
	Split System & Single Package			
	Tons \geq 20 Cap MBtuh \geq 240	11.25 \leq Tons $<$ 20 135 \leq MBtuh $<$ 240	5.42 \leq Tons $<$ 11.25 65 \leq MBtuh $<$ 135	Tons $<$ 5.42 MBtuh $<$ 65
Cap Tons Cap MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
Eff (S)EER				
16.0	5.99	4.55	4.28	2.81
15.0	5.33	3.89	3.62	2.00
14.9	5.27	3.82	3.55	1.93
14.8	5.18	3.73	3.47	1.82
14.7	5.13	3.67	3.40	1.75
14.6	5.04	3.58	3.33	1.64
14.5	4.97	3.51	3.24	1.55
14.4	4.90	3.44	3.19	1.46
14.3	4.81	3.37	3.10	1.37
14.2	4.73	3.28	3.02	1.28
14.1	4.66	3.20	2.93	1.17
14.0	4.57	3.11	2.86	1.08
13.9	4.50	3.04	2.77	0.97
13.8	4.41	2.95	2.68	
13.7	4.32	2.86	2.61	
13.6	4.25	2.79	2.52	
13.5	4.14	2.70	2.43	
13.4	4.05	2.59	2.34	
13.3	3.98	2.52	2.27	
13.2	3.89	2.43	2.16	
13.1	3.78	2.34	2.07	
13.0	3.69	2.23	1.98	
12.9	3.60	2.14	1.89	
12.8	3.51	2.05	1.80	
12.7	3.40	1.94	1.69	
12.6	3.31	1.85	1.60	
12.5	3.20	1.75	1.49	
12.4	3.10	1.64	1.39	
12.3	2.99	1.53	1.28	
12.2	2.88	1.42	1.17	
12.1	2.77	1.31	1.06	
12.0	2.66	1.21	0.95	
11.9	2.56	1.10		
11.8	2.45	0.99		
11.7	2.32			
11.6	2.21			
11.5	2.09			
11.4	1.96			
11.3	1.84			
11.2	1.73			
11.1	1.58			
11.0	1.46			
10.9	1.31			
10.8	1.19			
10.7	1.06			

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

L-000K

<i>Gulf Power Incentives DX VRF Heat Pumps - Air Cooled</i>							
Dx Unitary	AHRI 1230						
	Multisplit			Multisplit w/Heat Recovery			Condensing Unit
Cap Tons Cap MBtuh	Tons ≥ 20 MBtuh ≥ 240	11.25 ≤ Tons < 20 35 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons ≥ 20 MBtuh ≥ 240	11.25 ≤ Tons < 20 135 ≤ MBtuh < 240	5.42 ≤ Tons < 11.25 65 ≤ MBtuh < 135	Tons < 5.42 MBtuh < 65
Eff (S)EER	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
16.0	6.84	5.09	4.55	7.20	5.38	4.82	2.81
15.0	6.17	4.43	3.89	6.53	4.72	4.16	2.00
14.9	6.10	4.36	3.82	6.48	4.64	4.09	1.93
14.8	6.03	4.28	3.73	6.39	4.57	4.00	1.82
14.7	5.96	4.21	3.67	6.32	4.50	3.94	1.75
14.6	5.89	4.14	3.58	6.25	4.43	3.85	1.64
14.5	5.80	4.05	3.51	6.17	4.34	3.78	1.55
14.4	5.74	4.00	3.44	6.10	4.28	3.71	1.46
14.3	5.65	3.91	3.37	6.01	4.19	3.64	1.37
14.2	5.58	3.83	3.28	5.94	4.12	3.55	1.28
14.1	5.49	3.74	3.20	5.87	4.03	3.47	1.17
14.0	5.42	3.67	3.11	5.78	3.96	3.38	1.08
13.9	5.35	3.58	3.04	5.71	3.89	3.31	0.97
13.8	5.24	3.49	2.95	5.60	3.78	3.22	
13.7	5.17	3.42	2.86	5.53	3.71	3.13	
13.6	5.08	3.33	2.79	5.45	3.62	3.06	
13.5	4.99	3.24	2.70	5.35	3.53	2.97	
13.4	4.90	3.15	2.59	5.26	3.44	2.86	
13.3	4.82	3.06	2.52	5.18	3.37	2.79	
13.2	4.72	2.97	2.43	5.09	3.26	2.70	
13.1	4.63	2.88	2.34	4.99	3.17	2.61	
13.0	4.54	2.79	2.23	4.90	3.08	2.50	
12.9	4.45	2.70	2.14	4.81	2.99	2.41	
12.8	4.36	2.61	2.05	4.72	2.90	2.32	
12.7	4.25	2.50	1.94	4.61	2.79	2.21	
12.6	4.16	2.39	1.85	4.52	2.70	2.12	
12.5	4.05	2.30	1.75	4.41	2.59	2.02	
12.4	3.94	2.20	1.64	4.30	2.48	1.91	
12.3	3.83	2.09	1.53	4.19	2.38	1.80	
12.2	3.73	1.98	1.42	4.09	2.27	1.69	
12.1	3.62	1.87	1.31	3.98	2.16	1.58	
12.0	3.51	1.76	1.21	3.87	2.05	1.48	
11.9	3.40	1.66	1.10	3.76	1.94	1.37	
11.8	3.28	1.53	0.99	3.65	1.82	1.26	
11.7	3.17	1.42		3.53	1.71	1.13	
11.6	3.06	1.31		3.42	1.60	1.03	
11.5	2.93	1.19		3.29	1.48		
11.4	2.81	1.06		3.17	1.35		
11.3	2.68	0.94		3.04	1.22		
11.2	2.56			2.93	1.10		
11.1	2.43			2.79	0.97		
11.0	2.30			2.66			
10.9	2.16			2.52			
10.8	2.03			2.39			
10.7	1.89			2.25			
10.6	1.75			2.11			
10.5	1.60			1.96			
10.4	1.46			1.82			
10.3	1.31			1.67			
10.2	1.17			1.53			
10.1				1.37			
10.0				1.21			

- Notes
1. One Ton = 12 MBtuh
 2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Floor Mounted - Air Cooled</i>							
		ANSI / ASHRAE 1360					
		Downflow with or without Economizer			UpFlow - Ducted With or Without Economizer		
Cap Tons => Cap MBtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	7.56	5.87	5.06	7.81	6.08	5.26
12.0	3.517	6.53	4.84	4.03	6.79	5.06	4.23
11.0	3.224	5.33	3.64	2.83	5.58	3.85	3.02
10.9	3.195	5.18	3.49	2.68	5.45	3.71	2.88
10.8	3.165	5.06	3.37	2.56	5.31	3.58	2.75
10.7	3.136	4.93	3.22	2.43	5.18	3.44	2.61
10.6	3.107	4.79	3.08	2.27	5.04	3.29	2.47
10.5	3.077	4.63	2.93	2.12	4.90	3.15	2.32
10.4	3.048	4.48	2.79	1.98	4.73	3.01	2.18
10.3	3.019	4.34	2.65	1.84	4.59	2.86	2.03
10.2	2.989	4.19	2.50	1.69	4.45	2.72	1.89
10.1	2.960	4.03	2.34	1.53	4.28	2.56	1.73
10.0	2.931	3.87	2.18	1.37	4.12	2.39	1.57
9.9	2.902	3.71	2.02	1.21	3.96	2.23	1.40
9.8	2.872	3.55	1.85		3.82	2.07	1.24
9.7	2.843	3.38	1.69		3.64	1.89	1.06
9.6	2.814	3.20	1.51		3.46	1.73	
9.5	2.784	3.02	1.33		3.29	1.55	
9.4	2.755	2.84	1.15		3.10	1.37	
9.3	2.726	2.66			2.93	1.19	
9.2	2.696	2.48			2.74	1.01	
9.1	2.667	2.29			2.54		
9.0	2.638	2.11			2.36		
8.9	2.608	1.89			2.16		
8.8	2.579	1.69			1.94		
8.7	2.550	1.49			1.75		
8.6	2.521	1.28			1.53		
8.5	2.491				1.30		
8.4	2.462						
8.3	2.433						
8.2	2.403						
8.1	2.374						
8.0	2.345						
7.9	2.315						
7.8	2.286						
7.7	2.257						
7.6	2.227						
7.5	2.198						
7.4	2.169						
7.3	2.140						
7.2	2.110						
7.1	2.081						
7.0	2.052						
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Floor Mounted - Air Cooled</i>										
		ANSI / ASHRAE 1360								
		Horizontal With or Without Economizer			UpFlow - NonDucted With Economizer			UpFlow - NonDucted Without Economizer		
Cap Tons => Cap MBtuh=>		Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	6.68	6.08	5.38	13.61	11.27	10.13	12.51	10.69	9.41
12.0	3.517	5.65	5.06	4.36	12.58	10.22	9.11	11.48	9.67	8.37
11.0	3.224	4.45	3.85	3.15	11.36	9.02	7.88	10.26	8.44	7.16
10.9	3.195	4.30	3.71	3.02	11.23	8.89	7.76	10.13	8.32	7.04
10.8	3.165	4.18	3.58	2.88	11.09	8.75	7.63	9.99	8.17	6.89
10.7	3.136	4.03	3.44	2.75	10.96	8.62	7.49	9.86	8.05	6.77
10.6	3.107	3.89	3.29	2.61	10.82	8.48	7.34	9.72	7.90	6.62
10.5	3.077	3.74	3.15	2.45	10.67	8.33	7.20	9.58	7.76	6.48
10.4	3.048	3.60	3.01	2.30	10.53	8.17	7.06	9.43	7.60	6.32
10.3	3.019	3.46	2.86	2.16	10.37	8.03	6.91	9.27	7.45	6.17
10.2	2.989	3.31	2.72	2.02	10.22	7.88	6.75	9.13	7.31	6.03
10.1	2.960	3.15	2.56	1.85	10.06	7.72	6.61	8.96	7.15	5.87
10.0	2.931	2.99	2.39	1.69	9.90	7.56	6.44	8.82	6.98	5.71
9.9	2.902	2.83	2.23	1.53	9.76	7.40	6.28	8.66	6.82	5.54
9.8	2.872	2.66	2.07	1.37	9.59	7.25	6.12	8.50	6.68	5.40
9.7	2.843	2.48	1.89	1.21	9.41	7.07	5.94	8.32	6.50	5.22
9.6	2.814	2.32	1.73		9.23	6.89	5.78	8.15	6.32	5.04
9.5	2.784	2.14	1.55		9.07	6.73	5.60	7.97	6.16	4.88
9.4	2.755	1.96	1.37		8.87	6.53	5.42	7.79	5.96	4.68
9.3	2.726	1.78	1.19		8.71	6.37	5.24	7.61	5.80	4.52
9.2	2.696	1.60			8.51	6.17	5.06	7.43	5.60	4.32
9.1	2.667	1.40			8.32	5.98	4.86	7.22	5.40	4.12
9.0	2.638	1.21			8.14	5.80	4.66	7.04	5.22	3.94
8.9	2.608				7.94	5.60	4.46	6.84	5.02	3.74
8.8	2.579				7.72	5.38	4.25	6.62	4.81	3.53
8.7	2.550				7.52	5.18	4.05	6.43	4.61	3.33
8.6	2.521				7.31	4.97	3.83	6.21	4.39	3.11
8.5	2.491				7.07	4.73	3.62	5.99	4.16	2.88
8.4	2.462				6.86	4.52	3.38	5.76	3.94	2.66
8.3	2.433				6.62	4.28	3.15	5.53	3.71	2.43
8.2	2.403				6.41	4.05	2.93	5.31	3.49	2.20
8.1	2.374				6.16	3.82	2.70	5.06	3.24	1.96
8.0	2.345				5.90	3.56	2.43	4.81	2.99	1.71
7.9	2.315				5.65	3.31	2.18	4.55	2.74	1.46
7.8	2.286				5.40	3.06	1.93	4.30	2.48	
7.7	2.257				5.13	2.79	1.67	4.03	2.21	
7.6	2.227				4.86	2.52	1.39	3.76	1.94	
7.5	2.198				4.57	2.23		3.47	1.66	
7.4	2.169				4.28	1.94		3.19	1.37	
7.3	2.140				4.00	1.64		2.90		
7.2	2.110				3.69			2.59		
7.1	2.081				3.37			2.29		
7.0	2.052				3.06			1.96		
6.9	2.022				2.72			1.62		
6.8	1.993				2.38					
6.7	1.964				2.03					
6.6	1.934				1.67					
6.5	1.905									

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Air Cooled - Free Air discharge Condenser WO Fluid Economizer</i>							
		ANSI / ASHRAE 1360					
		Free Air Discharge Condenser					
		Ducted			Nonducted		
	Cap Tons => Cap MBtuh=>	Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	12.11	10.91	10.57	11.86	10.57	10.24
12.0	3.517	11.09	9.88	9.54	10.84	9.54	9.22
11.0	3.224	9.88	8.68	8.33	9.63	8.33	7.99
10.9	3.195	9.74	8.53	8.19	9.49	8.19	7.87
10.8	3.165	9.61	8.41	8.06	9.36	8.06	7.74
10.7	3.136	9.49	8.26	7.92	9.23	7.92	7.60
10.6	3.107	9.32	8.12	7.78	9.09	7.78	7.45
10.5	3.077	9.18	7.97	7.63	8.93	7.63	7.31
10.4	3.048	9.04	7.83	7.49	8.78	7.49	7.16
10.3	3.019	8.89	7.69	7.34	8.64	7.34	7.02
10.2	2.989	8.75	7.54	7.20	8.50	7.20	6.86
10.1	2.960	8.59	7.38	7.04	8.33	7.04	6.71
10.0	2.931	8.42	7.22	6.88	8.17	6.88	6.55
9.9	2.902	8.26	7.06	6.71	8.01	6.71	6.39
9.8	2.872	8.10	6.89	6.55	7.85	6.55	6.23
9.7	2.843	7.94	6.73	6.39	7.69	6.39	6.05
9.6	2.814	7.76	6.55	6.21	7.51	6.21	5.89
9.5	2.784	7.58	6.37	6.03	7.33	6.03	5.71
9.4	2.755	7.40	6.19	5.85	7.15	5.85	5.53
9.3	2.726	7.22	6.01	5.67	6.97	5.67	5.35
9.2	2.696	7.04	5.83	5.49	6.79	5.49	5.17
9.1	2.667	6.84	5.63	5.29	6.59	5.29	4.97
9.0	2.638	6.66	5.44	5.09	6.41	5.09	4.77
8.9	2.608	6.44	5.24	4.90	6.21	4.90	4.57
8.8	2.579	6.25	5.02	4.68	5.99	4.68	4.36
8.7	2.550	6.03	4.82	4.48	5.80	4.48	4.16
8.6	2.521	5.83	4.61	4.27	5.58	4.27	3.94
8.5	2.491	5.60	4.39	4.05	5.35	4.05	3.73
8.4	2.462	5.36	4.16	3.82	5.13	3.82	3.49
8.3	2.433	5.15	3.94	3.60	4.90	3.60	3.26
8.2	2.403	4.91	3.71	3.37	4.66	3.37	3.04
8.1	2.374	4.68	3.47	3.13	4.43	3.13	2.81
8.0	2.345	4.43	3.22	2.88	4.18	2.88	2.54
7.9	2.315	4.18	2.97	2.63	3.92	2.63	2.29
7.8	2.286	3.92	2.72	2.38	3.67	2.38	2.03
7.7	2.257	3.65	2.45	2.11	3.40	2.11	1.76
7.6	2.227	3.37	2.16	1.82	3.11	1.82	1.49
7.5	2.198	3.10	1.89	1.55	2.84	1.55	
7.4	2.169	2.79	1.58		2.56		
7.3	2.140	2.50			2.25		
7.2	2.110	2.20			1.94		
7.1	2.081	1.89			1.64		
7.0	2.052	1.57					
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Air Cooled - Free Air discharge Condenser W Fluid Economizer</i>							
		Free Air Discharge Condenser with Fluid Economizer					
		Ducted			Nonducted		
Cap Tons => Cap MBtuh=>		Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	12.78	11.50	11.03	12.51	11.14	10.69
12.0	3.517	11.75	10.48	10.01	11.48	10.12	9.67
11.0	3.224	10.53	9.25	8.78	10.26	8.91	8.44
10.9	3.195	10.40	9.13	8.66	10.13	8.77	8.32
10.8	3.165	10.26	9.00	8.51	9.99	8.64	8.17
10.7	3.136	10.13	8.86	8.39	9.86	8.50	8.05
10.6	3.107	9.99	8.71	8.24	9.72	8.35	7.90
10.5	3.077	9.85	8.57	8.10	9.58	8.21	7.76
10.4	3.048	9.70	8.42	7.94	9.43	8.06	7.60
10.3	3.019	9.54	8.28	7.79	9.27	7.92	7.45
10.2	2.989	9.40	8.12	7.65	9.13	7.78	7.31
10.1	2.960	9.23	7.96	7.49	8.96	7.61	7.15
10.0	2.931	9.07	7.81	7.33	8.82	7.45	6.98
9.9	2.902	8.93	7.65	7.16	8.66	7.29	6.82
9.8	2.872	8.77	7.49	7.02	8.50	7.13	6.68
9.7	2.843	8.59	7.31	6.84	8.32	6.95	6.50
9.6	2.814	8.41	7.15	6.66	8.15	6.79	6.32
9.5	2.784	8.24	6.97	6.50	7.97	6.61	6.16
9.4	2.755	8.05	6.79	6.30	7.79	6.43	5.96
9.3	2.726	7.88	6.61	6.14	7.61	6.25	5.80
9.2	2.696	7.69	6.43	5.94	7.43	6.07	5.60
9.1	2.667	7.49	6.21	5.74	7.22	5.87	5.40
9.0	2.638	7.31	6.03	5.56	7.04	5.67	5.22
8.9	2.608	7.11	5.83	5.36	6.84	5.47	5.02
8.8	2.579	6.89	5.62	5.15	6.62	5.26	4.81
8.7	2.550	6.70	5.42	4.95	6.43	5.06	4.61
8.6	2.521	6.48	5.20	4.73	6.21	4.84	4.39
8.5	2.491	6.25	4.99	4.50	5.99	4.63	4.16
8.4	2.462	6.03	4.75	4.28	5.76	4.39	3.94
8.3	2.433	5.80	4.52	4.05	5.53	4.18	3.71
8.2	2.403	5.58	4.30	3.83	5.31	3.94	3.49
8.1	2.374	5.33	4.05	3.58	5.06	3.71	3.24
8.0	2.345	5.08	3.80	3.33	4.81	3.46	2.99
7.9	2.315	4.82	3.55	3.08	4.55	3.19	2.74
7.8	2.286	4.57	3.29	2.83	4.30	2.93	2.48
7.7	2.257	4.30	3.02	2.56	4.03	2.68	2.21
7.6	2.227	4.03	2.75	2.29	3.76	2.39	1.94
7.5	2.198	3.74	2.47	2.00	3.47	2.11	1.66
7.4	2.169	3.46	2.18	1.71	3.19	1.82	1.37
7.3	2.140	3.17	1.89	1.40	2.90	1.53	
7.2	2.110	2.84	1.58		2.59		
7.1	2.081	2.54			2.29		
7.0	2.052	2.23			1.96		
6.9	2.022	1.89			1.62		
6.8	1.993	1.55					
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Air Cooled - Ducted Condenser WO Fluid Economizer</i>							
		ANSI / ASHRAE 1360					
		Ducted Condenser					
		Ducted			Nonducted		
Cap Tons => Cap MBtuh=>		Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	14.80	13.32	12.91	14.49	12.91	12.51
12.0	3.517	13.77	12.29	11.88	13.46	11.88	11.48
11.0	3.224	12.56	11.09	10.67	12.26	10.67	10.26
10.9	3.195	12.42	10.94	10.53	12.11	10.53	10.13
10.8	3.165	12.29	10.82	10.40	11.99	10.40	9.99
10.7	3.136	12.17	10.67	10.26	11.84	10.26	9.86
10.6	3.107	12.01	10.53	10.12	11.70	10.12	9.72
10.5	3.077	11.86	10.39	9.97	11.56	9.97	9.58
10.4	3.048	11.72	10.24	9.83	11.41	9.83	9.43
10.3	3.019	11.57	10.10	9.68	11.27	9.68	9.27
10.2	2.989	11.43	9.95	9.54	11.12	9.54	9.13
10.1	2.960	11.27	9.79	9.38	10.96	9.38	8.96
10.0	2.931	11.11	9.63	9.22	10.80	9.22	8.82
9.9	2.902	10.94	9.47	9.05	10.64	9.05	8.66
9.8	2.872	10.78	9.31	8.89	10.48	8.89	8.50
9.7	2.843	10.62	9.13	8.73	10.31	8.73	8.32
9.6	2.814	10.44	8.96	8.55	10.13	8.55	8.15
9.5	2.784	10.26	8.78	8.37	9.95	8.37	7.97
9.4	2.755	10.08	8.60	8.19	9.77	8.19	7.79
9.3	2.726	9.90	8.42	8.01	9.59	8.01	7.61
9.2	2.696	9.72	8.24	7.83	9.41	7.83	7.43
9.1	2.667	9.52	8.05	7.63	9.22	7.63	7.22
9.0	2.638	9.34	7.85	7.43	9.02	7.43	7.04
8.9	2.608	9.13	7.65	7.24	8.82	7.24	6.84
8.8	2.579	8.93	7.43	7.02	8.60	7.02	6.62
8.7	2.550	8.71	7.24	6.82	8.41	6.82	6.43
8.6	2.521	8.51	7.02	6.61	8.19	6.61	6.21
8.5	2.491	8.28	6.80	6.39	7.97	6.39	5.99
8.4	2.462	8.05	6.57	6.16	7.74	6.16	5.76
8.3	2.433	7.83	6.35	5.94	7.52	5.94	5.53
8.2	2.403	7.60	6.12	5.71	7.29	5.71	5.31
8.1	2.374	7.36	5.89	5.47	7.06	5.47	5.06
8.0	2.345	7.11	5.63	5.22	6.80	5.22	4.81
7.9	2.315	6.86	5.36	4.97	6.55	4.97	4.55
7.8	2.286	6.61	5.11	4.72	6.30	4.72	4.30
7.7	2.257	6.34	4.86	4.45	6.03	4.45	4.03
7.6	2.227	6.05	4.57	4.16	5.74	4.16	3.76
7.5	2.198	5.78	4.28	3.89	5.47	3.89	3.47
7.4	2.169	5.47	4.00	3.58	5.17	3.58	3.19
7.3	2.140	5.18	3.71	3.29	4.88	3.29	2.90
7.2	2.110	4.88	3.40	2.99	4.57	2.99	2.59
7.1	2.081	4.57	3.10	2.68	4.27	2.68	2.29
7.0	2.052	4.25	2.77	2.36	3.94	2.36	1.96
6.9	2.022	3.92	2.45	2.03	3.62	2.03	1.62
6.8	1.993	3.56	2.09	1.67	3.26	1.67	
6.7	1.964	3.22	1.75		2.92		
6.6	1.934	2.86			2.56		
6.5	1.905	2.48			2.18		
6.4	1.876	2.11			1.80		
6.3	1.846	1.71					
6.2	1.817						
6.1	1.788						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Air Cooled - Ducted Condenser W Fluid Economizer</i>							
		Ducted Condenser with Fluid Economizer					
		Ducted			Nonducted		
Cap Tons => Cap MBtuh=>		Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	15.61	14.04	13.46	15.28	13.61	13.05
12.0	3.517	14.58	13.01	12.44	14.26	12.58	12.02
11.0	3.224	13.37	11.81	11.21	13.05	11.36	10.80
10.9	3.195	13.23	11.66	11.09	12.91	11.23	10.67
10.8	3.165	13.10	11.54	10.96	12.78	11.09	10.53
10.7	3.136	12.98	11.39	10.82	12.64	10.96	10.40
10.6	3.107	12.82	11.25	10.67	12.49	10.82	10.26
10.5	3.077	12.67	11.11	10.53	12.35	10.67	10.12
10.4	3.048	12.53	10.96	10.39	12.20	10.53	9.97
10.3	3.019	12.38	10.82	10.24	12.06	10.37	9.81
10.2	2.989	12.24	10.67	10.08	11.92	10.22	9.67
10.1	2.960	12.08	10.51	9.94	11.75	10.06	9.50
10.0	2.931	11.92	10.35	9.77	11.59	9.90	9.34
9.9	2.902	11.75	10.19	9.61	11.43	9.76	9.20
9.8	2.872	11.59	10.03	9.45	11.27	9.59	9.04
9.7	2.843	11.43	9.85	9.27	11.09	9.41	8.86
9.6	2.814	11.25	9.68	9.11	10.93	9.23	8.68
9.5	2.784	11.07	9.50	8.93	10.75	9.07	8.51
9.4	2.755	10.89	9.32	8.75	10.57	8.87	8.32
9.3	2.726	10.71	9.14	8.57	10.39	8.71	8.15
9.2	2.696	10.53	8.96	8.39	10.21	8.51	7.96
9.1	2.667	10.33	8.77	8.17	10.01	8.32	7.76
9.0	2.638	10.13	8.57	7.99	9.81	8.14	7.58
8.9	2.608	9.94	8.37	7.79	9.61	7.94	7.38
8.8	2.579	9.72	8.15	7.58	9.40	7.72	7.16
8.7	2.550	9.52	7.96	7.38	9.20	7.52	6.97
8.6	2.521	9.32	7.74	7.16	8.98	7.31	6.75
8.5	2.491	9.09	7.52	6.95	8.77	7.07	6.52
8.4	2.462	8.86	7.29	6.71	8.53	6.86	6.30
8.3	2.433	8.64	7.07	6.48	8.32	6.62	6.07
8.2	2.403	8.41	6.84	6.26	8.08	6.41	5.85
8.1	2.374	8.17	6.61	6.01	7.85	6.16	5.60
8.0	2.345	7.92	6.35	5.76	7.60	5.90	5.35
7.9	2.315	7.67	6.10	5.51	7.33	5.65	5.09
7.8	2.286	7.42	5.85	5.26	7.07	5.40	4.84
7.7	2.257	7.15	5.58	4.99	6.82	5.13	4.57
7.6	2.227	6.86	5.29	4.72	6.53	4.86	4.30
7.5	2.198	6.59	5.02	4.43	6.25	4.57	4.01
7.4	2.169	6.28	4.72	4.14	5.96	4.28	3.73
7.3	2.140	5.99	4.43	3.85	5.67	4.00	3.44
7.2	2.110	5.69	4.12	3.55	5.36	3.69	3.13
7.1	2.081	5.38	3.82	3.24	5.06	3.37	2.81
7.0	2.052	5.06	3.49	2.92	4.73	3.06	2.50
6.9	2.022	4.73	3.17	2.57	4.39	2.72	2.16
6.8	1.993	4.37	2.81	2.23	4.05	2.38	1.82
6.7	1.964	4.03	2.47	1.89	3.71	2.03	1.48
6.6	1.934	3.67	2.11		3.35	1.67	
6.5	1.905	3.29	1.73		2.97		
6.4	1.876	2.92			2.59		
6.3	1.846	2.52			2.20		
6.2	1.817	2.11			1.78		
6.1	1.788	1.69					

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Water Cooled Condenser WO Fluid Economizer</i>							
		ANSI / ASHRAE 1360					
		Water Cooled Condenser Condenser					
		Ducted			Nonducted		
	Cap Tons => Cap Mbtuh=>	Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	5.42 ≤ Tons < 2.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	9.20	8.26	7.40	9.02	7.99	7.15
12.0	3.517	8.17	7.24	6.37	7.99	6.97	6.12
11.0	3.224	6.97	6.03	5.15	6.77	5.76	4.91
10.9	3.195	6.84	5.89	5.02	6.64	5.62	4.79
10.8	3.165	6.70	5.76	4.90	6.50	5.49	4.64
10.7	3.136	6.57	5.62	4.75	6.37	5.35	4.52
10.6	3.107	6.43	5.47	4.61	6.23	5.20	4.37
10.5	3.077	6.26	5.33	4.46	6.08	5.06	4.21
10.4	3.048	6.12	5.18	4.32	5.94	4.91	4.07
10.3	3.019	5.98	5.04	4.18	5.78	4.77	3.92
10.2	2.989	5.83	4.90	4.03	5.63	4.63	3.78
10.1	2.960	5.67	4.73	3.87	5.47	4.46	3.62
10.0	2.931	5.51	4.57	3.71	5.31	4.30	3.46
9.9	2.902	5.35	4.41	3.55	5.17	4.14	3.29
9.8	2.872	5.18	4.25	3.38	5.00	3.98	3.13
9.7	2.843	5.02	4.07	3.20	4.82	3.82	2.97
9.6	2.814	4.84	3.91	3.04	4.64	3.64	2.79
9.5	2.784	4.68	3.73	2.86	4.48	3.46	2.61
9.4	2.755	4.48	3.55	2.68	4.28	3.28	2.43
9.3	2.726	4.32	3.37	2.50	4.12	3.10	2.25
9.2	2.696	4.12	3.19	2.32	3.92	2.92	2.07
9.1	2.667	3.92	2.99	2.12	3.73	2.72	1.87
9.0	2.638	3.74	2.79	1.93	3.55	2.52	1.69
8.9	2.608	3.55	2.59	1.73	3.35	2.32	1.49
8.8	2.579	3.33	2.38	1.51	3.13	2.11	1.28
8.7	2.550	3.13	2.18	1.31	2.93	1.91	
8.6	2.521	2.92	1.96		2.72	1.69	
8.5	2.491	2.68	1.75		2.48	1.48	
8.4	2.462	2.47	1.51		2.27	1.24	
8.3	2.433	2.23	1.30		2.03		
8.2	2.403	2.00			1.82		
8.1	2.374	1.76			1.57		
8.0	2.345	1.51			1.31		
7.9	2.315	1.26					
7.8	2.286						
7.7	2.257						
7.6	2.227						
7.5	2.198						
7.4	2.169						
7.3	2.140						
7.2	2.110						
7.1	2.081						
7.0	2.052						
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Water Cooled Condenser W Fluid Economizer</i>							
		Water Cooled Condenser with Fluid Economizer					
		Ducted			Nonducted		
	Cap Tons => Cap MBtuh=>	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	9.70	8.73	7.81	9.41	8.44	7.56
12.0	3.517	8.68	7.70	6.79	8.37	7.42	6.53
11.0	3.224	7.47	6.48	5.58	7.16	6.21	5.33
10.9	3.195	7.34	6.35	5.45	7.04	6.07	5.18
10.8	3.165	7.20	6.21	5.31	6.89	5.94	5.06
10.7	3.136	7.07	6.08	5.18	6.77	5.80	4.93
10.6	3.107	6.93	5.94	5.04	6.62	5.65	4.79
10.5	3.077	6.77	5.80	4.90	6.48	5.51	4.63
10.4	3.048	6.62	5.63	4.73	6.32	5.36	4.48
10.3	3.019	6.48	5.49	4.59	6.17	5.22	4.34
10.2	2.989	6.34	5.35	4.45	6.03	5.08	4.19
10.1	2.960	6.17	5.18	4.28	5.87	4.91	4.03
10.0	2.931	6.01	5.02	4.12	5.71	4.75	3.87
9.9	2.902	5.85	4.88	3.96	5.54	4.59	3.71
9.8	2.872	5.69	4.72	3.82	5.40	4.43	3.55
9.7	2.843	5.53	4.54	3.64	5.22	4.27	3.38
9.6	2.814	5.35	4.36	3.46	5.04	4.09	3.20
9.5	2.784	5.18	4.19	3.29	4.88	3.91	3.02
9.4	2.755	4.99	4.00	3.10	4.68	3.73	2.84
9.3	2.726	4.82	3.83	2.93	4.52	3.55	2.66
9.2	2.696	4.63	3.64	2.74	4.32	3.37	2.48
9.1	2.667	4.43	3.44	2.54	4.12	3.17	2.29
9.0	2.638	4.25	3.26	2.36	3.94	2.97	2.11
8.9	2.608	4.05	3.06	2.16	3.74	2.77	1.89
8.8	2.579	3.83	2.84	1.94	3.53	2.56	1.69
8.7	2.550	3.64	2.65	1.75	3.33	2.36	1.49
8.6	2.521	3.42	2.43	1.53	3.11	2.14	1.28
8.5	2.491	3.19	2.20	1.30	2.88	1.93	
8.4	2.462	2.97	1.98		2.66	1.69	
8.3	2.433	2.74	1.75		2.43	1.48	
8.2	2.403	2.50	1.53		2.20	1.24	
8.1	2.374	2.27	1.28		1.96		
8.0	2.345	2.02			1.71		
7.9	2.315	1.76			1.46		
7.8	2.286	1.51					
7.7	2.257						
7.6	2.227						
7.5	2.198						
7.4	2.169						
7.3	2.140						
7.2	2.110						
7.1	2.081						
7.0	2.052						
6.9	2.022						
6.8	1.993						
6.7	1.964						
6.6	1.934						
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Glycol Cooled Condenser WO Fluid Economizer</i>							
		ANSI / ASHRAE 1360					
		Glycol Cooled Condenser					
		Ducted			Nonducted		
	Cap Tons => Cap Mbtuh=>	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	14.04	11.99	11.50	13.61	11.38	11.14
12.0	3.517	13.01	10.96	10.48	12.58	10.35	10.12
11.0	3.224	11.81	9.76	9.25	11.36	9.14	8.91
10.9	3.195	11.66	9.61	9.13	11.23	9.00	8.77
10.8	3.165	11.54	9.49	9.00	11.09	8.87	8.64
10.7	3.136	11.39	9.36	8.86	10.96	8.73	8.50
10.6	3.107	11.25	9.20	8.71	10.82	8.59	8.35
10.5	3.077	11.11	9.05	8.57	10.67	8.44	8.21
10.4	3.048	10.96	8.91	8.42	10.53	8.30	8.06
10.3	3.019	10.82	8.77	8.28	10.37	8.15	7.92
10.2	2.989	10.67	8.62	8.12	10.22	8.01	7.78
10.1	2.960	10.51	8.46	7.96	10.06	7.85	7.61
10.0	2.931	10.35	8.30	7.81	9.90	7.69	7.45
9.9	2.902	10.19	8.14	7.65	9.76	7.52	7.29
9.8	2.872	10.03	7.97	7.49	9.59	7.36	7.13
9.7	2.843	9.85	7.81	7.31	9.41	7.20	6.95
9.6	2.814	9.68	7.63	7.15	9.23	7.02	6.79
9.5	2.784	9.50	7.45	6.97	9.07	6.84	6.61
9.4	2.755	9.32	7.27	6.79	8.87	6.66	6.43
9.3	2.726	9.14	7.09	6.61	8.71	6.48	6.25
9.2	2.696	8.96	6.91	6.43	8.51	6.30	6.07
9.1	2.667	8.77	6.71	6.21	8.32	6.10	5.87
9.0	2.638	8.57	6.53	6.03	8.14	5.90	5.67
8.9	2.608	8.37	6.32	5.83	7.94	5.71	5.47
8.8	2.579	8.15	6.12	5.62	7.72	5.49	5.26
8.7	2.550	7.96	5.90	5.42	7.52	5.29	5.06
8.6	2.521	7.74	5.71	5.20	7.31	5.08	4.84
8.5	2.491	7.52	5.47	4.99	7.07	4.86	4.63
8.4	2.462	7.29	5.24	4.75	6.86	4.63	4.39
8.3	2.433	7.07	5.02	4.52	6.62	4.41	4.18
8.2	2.403	6.84	4.79	4.30	6.41	4.18	3.94
8.1	2.374	6.61	4.55	4.05	6.16	3.94	3.71
8.0	2.345	6.35	4.30	3.80	5.90	3.69	3.46
7.9	2.315	6.10	4.05	3.55	5.65	3.44	3.19
7.8	2.286	5.85	3.80	3.29	5.40	3.19	2.93
7.7	2.257	5.58	3.53	3.02	5.13	2.92	2.68
7.6	2.227	5.29	3.24	2.75	4.86	2.63	2.39
7.5	2.198	5.02	2.97	2.47	4.57	2.36	2.11
7.4	2.169	4.72	2.66	2.18	4.28	2.05	1.82
7.3	2.140	4.43	2.38	1.89	4.00	1.76	1.53
7.2	2.110	4.12	2.07	1.58	3.69	1.46	
7.1	2.081	3.82	1.76		3.37		
7.0	2.052	3.49	1.44		3.06		
6.9	2.022	3.17			2.72		
6.8	1.993	2.81			2.38		
6.7	1.964				2.03		
6.6	1.934				1.67		
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Ceiling Mounted - Glycol Cooled Condenser W Fluid Economizer</i>							
		ANSI / ASHRAE 1360					
		Glycol Cooled Condenser					
		Ducted			Nonducted		
	Cap Tons => Cap MBtuh=>	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29	Tons ≥ 5.42 MBtuh ≥ 65	2.42 ≤ Tons < 5.42 29 ≤ MBtuh < 65	Tons < 2.42 MBtuh < 29
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	14.80	12.64	12.11	14.35	11.99	11.75
12.0	3.517	13.77	11.61	11.09	13.32	10.96	10.71
11.0	3.224	12.56	10.40	9.88	12.10	9.76	9.50
10.9	3.195	12.42	10.26	9.74	11.97	9.61	9.38
10.8	3.165	12.29	10.13	9.61	11.83	9.49	9.23
10.7	3.136	12.17	9.99	9.49	11.70	9.36	9.11
10.6	3.107	12.01	9.85	9.32	11.56	9.20	8.96
10.5	3.077	11.86	9.70	9.18	11.41	9.05	8.82
10.4	3.048	11.72	9.56	9.04	11.27	8.91	8.66
10.3	3.019	11.57	9.41	8.89	11.11	8.77	8.51
10.2	2.989	11.43	9.27	8.75	10.96	8.62	8.37
10.1	2.960	11.27	9.11	8.59	10.80	8.46	8.21
10.0	2.931	11.11	8.95	8.42	10.64	8.30	8.05
9.9	2.902	10.94	8.78	8.26	10.49	8.14	7.88
9.8	2.872	10.78	8.62	8.10	10.33	7.97	7.74
9.7	2.843	10.62	8.44	7.94	10.15	7.81	7.56
9.6	2.814	10.44	8.28	7.76	9.97	7.63	7.38
9.5	2.784	10.26	8.10	7.58	9.81	7.45	7.22
9.4	2.755	10.08	7.92	7.40	9.61	7.27	7.02
9.3	2.726	9.90	7.74	7.22	9.45	7.09	6.86
9.2	2.696	9.72	7.56	7.04	9.25	6.91	6.66
9.1	2.667	9.52	7.36	6.84	9.05	6.71	6.46
9.0	2.638	9.34	7.16	6.66	8.87	6.53	6.28
8.9	2.608	9.13	6.97	6.44	8.68	6.32	6.08
8.8	2.579	8.93	6.75	6.25	8.46	6.12	5.87
8.7	2.550	8.71	6.55	6.03	8.26	5.90	5.67
8.6	2.521	8.51	6.34	5.83	8.05	5.71	5.45
8.5	2.491	8.28	6.12	5.60	7.81	5.47	5.22
8.4	2.462	8.05	5.89	5.36	7.60	5.24	5.00
8.3	2.433	7.83	5.67	5.15	7.36	5.02	4.77
8.2	2.403	7.60	5.44	4.91	7.15	4.79	4.54
8.1	2.374	7.36	5.20	4.68	6.89	4.55	4.30
8.0	2.345	7.11	4.95	4.43	6.64	4.30	4.05
7.9	2.315	6.86	4.70	4.18	6.39	4.05	3.80
7.8	2.286	6.61	4.43	3.92	6.14	3.80	3.55
7.7	2.257	6.34	4.18	3.65	5.87	3.53	3.28
7.6	2.227	6.05	3.89	3.37	5.60	3.24	3.01
7.5	2.198	5.78	3.62	3.10	5.31	2.97	2.72
7.4	2.169	5.47	3.31	2.79	5.02	2.66	2.43
7.3	2.140	5.18	3.02	2.50	4.73	2.38	2.12
7.2	2.110	4.88	2.72	2.20	4.43	2.07	1.82
7.1	2.081	4.57	2.41	1.89	4.10	1.76	1.51
7.0	2.052	4.25	2.09	1.57	3.80	1.44	
6.9	2.022	3.92	1.76		3.46		
6.8	1.993	3.56			3.11		
6.7	1.964	3.22			2.77		
6.6	1.934	2.86			2.41		
6.5	1.905	2.48			2.03		
6.4	1.876	2.11			1.64		
6.3	1.846	1.71					

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Water Cooled - Without Economizer</i>							
		ANSI / ASHRAE 1360					
		Downflow			Horizontal		
Cap Tons => Cap MBtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	5.26	4.88	4.32	5.72	5.18	4.50
12.0	3.517	4.23	3.85	3.29	4.70	4.16	3.47
11.9	3.488	4.12	3.74	3.19	4.59	4.07	3.37
11.8	3.458	4.00	3.62	3.08	4.48	3.94	3.26
11.7	3.429	3.89	3.49	2.95	4.36	3.82	3.13
11.6	3.400	3.78	3.38	2.84	4.25	3.71	3.02
11.5	3.370	3.65	3.28	2.72	4.14	3.60	2.90
11.4	3.341	3.53	3.13	2.59	4.00	3.46	2.77
11.3	3.312	3.40	3.02	2.47	3.87	3.35	2.65
11.2	3.283	3.28	2.90	2.36	3.76	3.22	2.54
11.1	3.253	3.15	2.77	2.21	3.62	3.08	2.39
11.0	3.224	3.02	2.63	2.09	3.49	2.95	2.27
10.9	3.195	2.88	2.50	1.94	3.37	2.83	2.12
10.8	3.165	2.75	2.36	1.82	3.22	2.68	2.00
10.7	3.136	2.61	2.23	1.69	3.10	2.56	1.85
10.6	3.107	2.47	2.09	1.53	2.95	2.41	1.71
10.5	3.077	2.32	1.94	1.39	2.79	2.25	1.57
10.4	3.048	2.18	1.80	1.24	2.65	2.11	1.42
10.3	3.019	2.03	1.64	1.10	2.50	1.96	1.28
10.2	2.989	1.89	1.49		2.36	1.82	1.13
10.1	2.960	1.73	1.33		2.20	1.66	
10.0	2.931	1.57	1.17		2.03	1.49	
9.9	2.902	1.40	1.03		1.87	1.33	
9.8	2.872	1.24			1.71	1.17	
9.7	2.843	1.06			1.55		
9.6	2.814				1.37		
9.5	2.784				1.21		
9.4	2.755						
9.3	2.726						
9.2	2.696						
9.1	2.667						
9.0	2.638						
8.9	2.608						
8.8	2.579						
8.7	2.550						
8.6	2.521						
8.5	2.491						
8.4	2.462						
8.3	2.433						
8.2	2.403						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Water Cooled - Without Economizer</i>							
		Upflow Ducted			Upflow Nonducted		
Cap Tons => Cap Mbtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	5.45	5.06	4.50	9.02	7.90	7.00
12.0	3.517	4.43	4.03	3.47	7.99	6.88	5.96
11.9	3.488	4.32	3.92	3.37	7.88	6.77	5.87
11.8	3.458	4.21	3.82	3.26	7.76	6.66	5.74
11.7	3.429	4.09	3.69	3.13	7.63	6.53	5.62
11.6	3.400	3.98	3.58	3.02	7.52	6.43	5.51
11.5	3.370	3.85	3.46	2.90	7.42	6.30	5.40
11.4	3.341	3.73	3.33	2.77	7.27	6.17	5.26
11.3	3.312	3.60	3.20	2.65	7.16	6.05	5.15
11.2	3.283	3.49	3.10	2.54	7.04	5.94	5.02
11.1	3.253	3.35	2.95	2.39	6.91	5.80	4.88
11.0	3.224	3.22	2.83	2.27	6.77	5.67	4.75
10.9	3.195	3.08	2.68	2.12	6.64	5.53	4.63
10.8	3.165	2.95	2.56	2.00	6.50	5.40	4.48
10.7	3.136	2.81	2.43	1.85	6.37	5.27	4.36
10.6	3.107	2.66	2.27	1.71	6.23	5.11	4.21
10.5	3.077	2.52	2.12	1.57	6.08	4.97	4.07
10.4	3.048	2.38	1.98	1.42	5.94	4.82	3.91
10.3	3.019	2.23	1.84	1.28	5.78	4.68	3.76
10.2	2.989	2.09	1.69	1.13	5.63	4.54	3.62
10.1	2.960	1.93	1.53		5.47	4.37	3.46
10.0	2.931	1.76	1.37		5.31	4.21	3.29
9.9	2.902	1.60	1.21		5.17	4.05	3.13
9.8	2.872	1.44			5.00	3.89	2.99
9.7	2.843	1.28			4.82	3.73	2.81
9.6	2.814	1.10			4.64	3.55	2.63
9.5	2.784				4.48	3.37	2.47
9.4	2.755				4.28	3.19	2.27
9.3	2.726				4.12	3.01	2.11
9.2	2.696				3.92	2.83	1.91
9.1	2.667				3.73	2.63	1.71
9.0	2.638				3.55	2.45	1.53
8.9	2.608				3.35	2.23	1.33
8.8	2.579				3.13	2.03	
8.7	2.550				2.93	1.82	
8.6	2.521				2.72	1.62	
8.5	2.491				2.48	1.39	
8.4	2.462				2.27	1.15	
8.3	2.433				2.03		
8.2	2.403				1.82		
8.1	2.374				1.57		
8.0	2.345				1.31		

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Water Cooled - With Economizer</i>							
		ANSI / ASHRAE 1360					
		Downflow			Horizontal		
	Cap Tons => Cap Mbtuh=>	Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
10.1	2.960	2.12	1.66	1.10	2.63	2.20	1.46
10.0	2.931	1.96	1.49		2.47	2.03	1.30
9.9	2.902	1.80	1.33		2.30	1.87	1.15
9.8	2.872	1.66	1.17		2.14	1.71	
9.7	2.843	1.48			1.96	1.55	
9.6	2.814	1.30			1.80	1.37	
9.5	2.784	1.13			1.62	1.21	
9.4	2.755				1.44		
9.3	2.726				1.26		
9.2	2.696						
9.1	2.667						
9.0	2.638						
8.9	2.608						
8.8	2.579						
8.7	2.550						
8.6	2.521						
8.5	2.491						
8.4	2.462						
8.3	2.433						
8.2	2.403						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Water Cooled - With Economizer</i>							
		Upflow Ducted			Upflow Hooded		
Cap Tons => Cap MBtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	5.87	5.38	4.81	9.81	8.62	7.65
12.0	3.517	4.84	4.36	3.78	8.78	7.60	6.62
11.9	3.488	4.73	4.25	3.67	8.68	7.49	6.52
11.8	3.458	4.63	4.14	3.56	8.57	7.38	6.39
11.7	3.429	4.50	4.01	3.44	8.44	7.25	6.28
11.6	3.400	4.39	3.91	3.33	8.33	7.15	6.17
11.5	3.370	4.27	3.80	3.20	8.21	7.04	6.05
11.4	3.341	4.14	3.65	3.08	8.08	6.89	5.92
11.3	3.312	4.01	3.53	2.95	7.96	6.77	5.80
11.2	3.283	3.91	3.42	2.84	7.85	6.66	5.67
11.1	3.253	3.76	3.28	2.70	7.70	6.52	5.54
11.0	3.224	3.64	3.15	2.57	7.58	6.39	5.42
10.9	3.195	3.49	3.02	2.43	7.43	6.26	5.27
10.8	3.165	3.37	2.88	2.30	7.31	6.12	5.15
10.7	3.136	3.22	2.75	2.16	7.18	5.99	5.00
10.6	3.107	3.08	2.61	2.02	7.04	5.85	4.86
10.5	3.077	2.93	2.45	1.87	6.88	5.69	4.72
10.4	3.048	2.79	2.30	1.73	6.73	5.54	4.57
10.3	3.019	2.65	2.16	1.58	6.59	5.40	4.43
10.2	2.989	2.50	2.02	1.44	6.44	5.26	4.28
10.1	2.960	2.34	1.85	1.28	6.28	5.09	4.12
10.0	2.931	2.18	1.69	1.12	6.12	4.93	3.96
9.9	2.902	2.02	1.53		5.96	4.77	3.80
9.8	2.872	1.85	1.37		5.80	4.61	3.64
9.7	2.843	1.69	1.21		5.63	4.45	3.46
9.6	2.814	1.51			5.45	4.27	3.29
9.5	2.784	1.33			5.27	4.10	3.11
9.4	2.755	1.15			5.09	3.91	2.93
9.3	2.726				4.91	3.74	2.75
9.2	2.696				4.73	3.55	2.57
9.1	2.667				4.54	3.35	2.38
9.0	2.638				4.36	3.17	2.18
8.9	2.608				4.14	2.97	1.98
8.8	2.579				3.94	2.75	1.76
8.7	2.550				3.74	2.56	1.57
8.6	2.521				3.53	2.34	1.35
8.5	2.491				3.29	2.11	
8.4	2.462				3.06	1.89	
8.3	2.433				2.84	1.66	
8.2	2.403				2.61	1.42	
8.1	2.374				2.38		
8.0	2.345				2.12		
7.9	2.315				1.87		
7.8	2.286				1.62		
7.7	2.257				1.35		

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Glycol Cooled - Without Economizer</i>							
		ANSI / ASHRAE 1360					
		Downflow			Horizontal		
Cap Tons => Cap Mbtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	8.91	8.62	6.01	9.20	9.20	6.61
12.0	3.517	7.88	7.60	4.99	8.17	8.17	5.58
11.9	3.488	7.78	7.49	4.88	8.08	8.08	5.47
11.8	3.458	7.67	7.38	4.75	7.96	7.96	5.35
11.7	3.429	7.54	7.25	4.64	7.83	7.83	5.24
11.6	3.400	7.43	7.15	4.54	7.72	7.72	5.13
11.5	3.370	7.31	7.04	4.41	7.61	7.61	5.00
11.4	3.341	7.18	6.89	4.28	7.47	7.47	4.88
11.3	3.312	7.06	6.77	4.16	7.34	7.34	4.75
11.2	3.283	6.95	6.66	4.03	7.24	7.24	4.63
11.1	3.253	6.80	6.52	3.91	7.09	7.09	4.50
11.0	3.224	6.68	6.39	3.78	6.97	6.97	4.36
10.9	3.195	6.53	6.26	3.64	6.84	6.84	4.23
10.8	3.165	6.41	6.12	3.51	6.70	6.70	4.10
10.7	3.136	6.26	5.99	3.37	6.57	6.57	3.96
10.6	3.107	6.12	5.85	3.22	6.43	6.43	3.82
10.5	3.077	5.98	5.69	3.08	6.26	6.26	3.67
10.4	3.048	5.83	5.54	2.93	6.12	6.12	3.53
10.3	3.019	5.69	5.40	2.79	5.98	5.98	3.38
10.2	2.989	5.54	5.26	2.65	5.83	5.83	3.22
10.1	2.960	5.38	5.09	2.48	5.67	5.67	3.08
10.0	2.931	5.22	4.93	2.32	5.51	5.51	2.92
9.9	2.902	5.06	4.77	2.16	5.35	5.35	2.75
9.8	2.872	4.90	4.61	2.00	5.18	5.18	2.59
9.7	2.843	4.73	4.45	1.82	5.02	5.02	2.41
9.6	2.814	4.55	4.27	1.66	4.84	4.84	2.25
9.5	2.784	4.37	4.10	1.48	4.68	4.68	2.07
9.4	2.755	4.19	3.91	1.30	4.48	4.48	1.89
9.3	2.726	4.01	3.74	1.12	4.32	4.32	1.71
9.2	2.696	3.83	3.55		4.12	4.12	1.53
9.1	2.667	3.64	3.35		3.92	3.92	1.31
9.0	2.638	3.44	3.17		3.74	3.74	1.13
8.9	2.608	3.24	2.97		3.55	3.55	
8.8	2.579	3.02	2.75		3.33	3.33	
8.7	2.550	2.83	2.56		3.13	3.13	
8.6	2.521	2.61	2.34		2.92	2.92	
8.5	2.491	2.39	2.11		2.68	2.68	
8.4	2.462	2.16	1.89		2.47	2.47	
8.3	2.433	1.94	1.66		2.23	2.23	
8.2	2.403	1.71	1.42		2.00	2.00	
8.1	2.374	1.48			1.76	1.76	
8.0	2.345	1.22			1.51	1.51	
7.9	2.315				1.26	1.26	
7.8	2.286						
7.7	2.257						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Glycol Cooled - Without Economizer</i>							
		Upflow Ducted			Upflow Nonducted		
Cap Tons => Cap MBtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	5.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	9.20	8.91	6.23	13.61	12.38	10.24
10.9	3.195	6.84	6.53	3.85	11.23	10.01	7.87
10.8	3.165	6.70	6.41	3.73	11.09	9.86	7.74
10.7	3.136	6.57	6.26	3.58	10.96	9.74	7.60
10.6	3.107	6.43	6.12	3.44	10.82	9.59	7.45
10.5	3.077	6.26	5.98	3.29	10.67	9.45	7.31
10.4	3.048	6.12	5.83	3.15	10.53	9.29	7.16
10.3	3.019	5.98	5.69	3.01	10.37	9.14	7.02
10.2	2.989	5.83	5.54	2.86	10.22	9.00	6.86
10.1	2.960	5.67	5.38	2.70	10.06	8.84	6.71
10.0	2.931	5.51	5.22	2.54	9.90	8.68	6.55
9.9	2.902	5.35	5.06	2.38	9.76	8.51	6.39
9.8	2.872	5.18	4.90	2.21	9.59	8.37	6.23
9.7	2.843	5.02	4.73	2.05	9.41	8.19	6.05
9.6	2.814	4.84	4.55	1.87	9.23	8.01	5.89
9.5	2.784	4.68	4.37	1.69	9.07	7.85	5.71
9.4	2.755	4.48	4.19	1.51	8.87	7.65	5.53
9.3	2.726	4.32	4.01	1.33	8.71	7.49	5.35
9.2	2.696	4.12	3.83	1.15	8.51	7.29	5.17
9.1	2.667	3.92	3.64		8.32	7.09	4.97
9.0	2.638	3.74	3.44		8.14	6.91	4.77
8.9	2.608	3.55	3.24		7.94	6.71	4.57
8.8	2.579	3.33	3.02		7.72	6.50	4.36
8.7	2.550	3.13	2.83		7.52	6.30	4.16
8.6	2.521	2.92	2.61		7.31	6.08	3.94
8.5	2.491	2.68	2.39		7.07	5.85	3.73
8.4	2.462	2.47	2.16		6.86	5.63	3.49
8.3	2.433	2.23	1.94		6.62	5.40	3.26
8.2	2.403	2.00	1.71		6.41	5.17	3.04
8.1	2.374	1.76	1.48		6.16	4.93	2.81
8.0	2.345	1.51	1.22		5.90	4.68	2.54
7.9	2.315	1.26			5.65	4.43	2.29
7.8	2.286				5.40	4.18	2.03
7.7	2.257				5.13	3.91	1.76
7.6	2.227				4.86	3.64	1.49
7.5	2.198				4.57	3.35	
7.4	2.169				4.28	3.06	
7.3	2.140				4.00	2.75	
7.2	2.110				3.69	2.45	
7.1	2.081				3.37	2.14	
7.0	2.052				3.06	1.84	
6.9	2.022				2.72	1.49	
6.8	1.993				2.38		
6.7	1.964				2.03		
6.6	1.934				1.67		
6.5	1.905						

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Incentives DX Computer Rm - Glycol Cooled - With Fluid Economizer</i>							
		ANSI / ASHRAE 1360					
		Downflow			Horizontal		
Cap Tons => Cap MBtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	6.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	9.50	9.11	6.37	10.03	10.03	6.91
12.0	3.517	8.48	8.08	5.35	9.00	9.00	5.89
11.9	3.488	8.37	7.97	5.24	8.89	8.89	5.78
11.8	3.458	8.24	7.85	5.13	8.77	8.77	5.65
11.7	3.429	8.14	7.74	5.00	8.66	8.66	5.54
11.6	3.400	8.03	7.63	4.90	8.55	8.55	5.44
11.5	3.370	7.90	7.51	4.77	8.42	8.42	5.31
11.4	3.341	7.78	7.38	4.64	8.30	8.30	5.18
11.3	3.312	7.65	7.25	4.52	8.17	8.17	5.06
11.2	3.283	7.52	7.13	4.41	8.05	8.05	4.93
11.1	3.253	7.40	7.00	4.27	7.92	7.92	4.81
11.0	3.224	7.27	6.88	4.14	7.79	7.79	4.68
10.9	3.195	7.13	6.73	4.00	7.65	7.65	4.54
10.8	3.165	7.00	6.61	3.87	7.52	7.52	4.41
10.7	3.136	6.86	6.46	3.74	7.38	7.38	4.27
10.6	3.107	6.71	6.32	3.58	7.24	7.24	4.12
10.5	3.077	6.57	6.17	3.44	7.09	7.09	3.98
10.4	3.048	6.43	6.03	3.29	6.95	6.95	3.83
10.3	3.019	6.28	5.89	3.15	6.80	6.80	3.69
10.2	2.989	6.14	5.74	3.01	6.66	6.66	3.55
10.1	2.960	5.98	5.58	2.84	6.50	6.50	3.38
10.0	2.931	5.81	5.42	2.68	6.34	6.34	3.22
9.9	2.902	5.65	5.26	2.52	6.17	6.17	3.06
9.8	2.872	5.49	5.09	2.36	6.01	6.01	2.90
9.7	2.843	5.31	4.91	2.20	5.83	5.83	2.74
9.6	2.814	5.15	4.75	2.02	5.67	5.67	2.56
9.5	2.784	4.97	4.57	1.84	5.49	5.49	2.38
9.4	2.755	4.79	4.39	1.66	5.31	5.31	2.20
9.3	2.726	4.61	4.21	1.48	5.13	5.13	2.02
9.2	2.696	4.43	4.03	1.30	4.95	4.95	1.84
9.1	2.667	4.23	3.83		4.75	4.75	1.64
9.0	2.638	4.03	3.64		4.55	4.55	1.44
8.9	2.608	3.83	3.44		4.36	4.36	1.24
8.8	2.579	3.62	3.22		4.14	4.14	
8.7	2.550	3.42	3.02		3.94	3.94	
8.6	2.521	3.20	2.81		3.73	3.73	
8.5	2.491	2.99	2.59		3.51	3.51	
8.4	2.462	2.75	2.36		3.28	3.28	
8.3	2.433	2.54	2.14		3.06	3.06	
8.2	2.403	2.30	1.91		2.83	2.83	
8.1	2.374	2.07	1.67		2.59	2.59	
8.0	2.345	1.82	1.42		2.34	2.34	
7.9	2.315	1.57			2.07	2.07	
7.8	2.286	1.30			1.82	1.82	
7.7	2.257				1.57	1.57	

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

<i>Gulf Power Company Incentives DX Computer Rm - Glycol Cooled - With Fluid Economizer</i>							
		Upflow Ducted			Upflow Nonducted		
Cap Tons => Cap Mbtuh=>		Tons ≥ 24.58 MBtuh ≥ 295	5.67 ≤ Tons < 24.58 80 ≤ MBtuh < 295	Tons < 6.67 MBtuh < 80	Tons ≥ 20 MBtuh ≥ 240	5.42 ≤ Tons < 20 65 ≤ MBtuh < 240	Tons < 5.42 MBtuh < 65
Sensible Efficiency EER	Sensible Efficiency SCOP	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh	Incentive \$/MBtuh
13.0	3.810	9.81	9.41	6.61	14.80	13.46	11.14
10.9	3.195	7.43	7.04	4.23	12.42	11.09	8.77
10.8	3.165	7.31	6.89	4.10	12.29	10.96	8.64
10.7	3.136	7.18	6.77	3.96	12.17	10.82	8.50
10.6	3.107	7.04	6.62	3.82	12.01	10.67	8.35
10.5	3.077	6.88	6.48	3.67	11.86	10.53	8.21
10.4	3.048	6.73	6.32	3.53	11.72	10.39	8.06
10.3	3.019	6.59	6.17	3.38	11.57	10.24	7.92
10.2	2.989	6.44	6.03	3.22	11.43	10.08	7.78
10.1	2.960	6.28	5.87	3.08	11.27	9.94	7.61
10.0	2.931	6.12	5.71	2.92	11.11	9.77	7.45
9.9	2.902	5.96	5.54	2.75	10.94	9.61	7.29
9.8	2.872	5.80	5.40	2.59	10.78	9.45	7.13
9.7	2.843	5.63	5.22	2.41	10.62	9.27	6.95
9.6	2.814	5.45	5.04	2.25	10.44	9.11	6.79
9.5	2.784	5.27	4.88	2.07	10.26	8.93	6.61
9.4	2.755	5.09	4.68	1.89	10.08	8.75	6.43
9.3	2.726	4.91	4.52	1.71	9.90	8.57	6.25
9.2	2.696	4.73	4.32	1.53	9.72	8.39	6.07
9.1	2.667	4.54	4.12	1.31	9.52	8.17	5.87
9.0	2.638	4.36	3.94	1.13	9.34	7.99	5.67
8.9	2.608	4.14	3.74		9.13	7.79	5.47
8.8	2.579	3.94	3.53		8.93	7.58	5.26
8.7	2.550	3.74	3.33		8.71	7.38	5.06
8.6	2.521	3.53	3.11		8.51	7.16	4.84
8.5	2.491	3.29	2.88		8.28	6.95	4.63
8.4	2.462	3.06	2.66		8.05	6.71	4.39
8.3	2.433	2.84	2.43		7.83	6.48	4.18
8.2	2.403	2.61	2.20		7.60	6.26	3.94
8.1	2.374	2.38	1.96		7.36	6.01	3.71
8.0	2.345	2.12	1.71		7.11	5.76	3.46
7.9	2.315	1.87	1.46		6.86	5.51	3.19
7.8	2.286	1.62			6.61	5.26	2.93
7.7	2.257	1.35			6.34	4.99	2.68
7.6	2.227				6.05	4.72	2.39
7.5	2.198				5.78	4.43	2.11
7.4	2.169				5.47	4.14	1.82
7.3	2.140				5.18	3.85	1.53
7.2	2.110				4.88	3.55	
7.1	2.081				4.57	3.24	
7.0	2.052				4.25	2.92	
6.9	2.022				3.92	2.57	
6.8	1.993				3.56	2.23	
6.7	1.964				3.22	1.89	
6.6	1.934				2.86	1.53	
6.5	1.905				2.48		
6.4	1.876				2.11		
6.3	1.846				1.71		

Notes

1. One Ton = 12 MBtuh
2. Efficiencies higher than maximum table ratings will be computed by Gulf Power

Gulf Power Business HVAC Program Tables

ERV Incentive Tables

Energy Recovery Ventilator Incentive Table - HVAC Systems							
\$ Per Cfm Air Flow							
Based on AHRI Standard 1060							
AHRI Net Thermal Effectiveness Rating ==>							
	50% to 54%	55% to 59%	60% to 64%	65% to 69%	70% to 74%	75% to 79%	80% or more
AHRI PD Inches	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm	\$ per cfm
0.1	2.81	3.13	3.44	3.75	4.06	4.38	4.69
0.2	2.75	3.07	3.38	3.69	4.01	4.32	4.63
0.3	2.70	3.01	3.32	3.63	3.95	4.26	4.57
0.4	2.64	2.95	3.26	3.58	3.89	4.20	4.51
0.5	2.58	2.89	3.21	3.52	3.83	4.14	4.46
0.6	2.52	2.83	3.15	3.46	3.77	4.09	4.40
0.7	2.46	2.78	3.09	3.40	3.71	4.03	4.34
0.8	2.41	2.72	3.03	3.34	3.66	3.97	4.28
0.9	2.35	2.66	2.97	3.29	3.60	3.91	4.22
1.0	2.29	2.60	2.91	3.23	3.54	3.85	4.17
1.1	2.23	2.54	2.86	3.17	3.48	3.79	4.11
1.2	2.17	2.49	2.80	3.11	3.42	3.74	4.05
1.3	2.12	2.43	2.74	3.05	3.37	3.68	3.99
1.4	2.06	2.37	2.68	3.00	3.31	3.62	3.93
1.5	2.00	2.31	2.62	2.94	3.25	3.56	3.87
1.6	1.94	2.25	2.57	2.88	3.19	3.50	3.82
1.7	1.88	2.20	2.51	2.82	3.13	3.45	3.76
1.8	1.82	2.14	2.45	2.76	3.08	3.39	3.70
1.9	1.77	2.08	2.39	2.70	3.02	3.33	3.64
2.0	1.71	2.02	2.33	2.65	2.96	3.27	3.58

- Notes
1. The AHRI Net Total Thermal Effectiveness for the cooling condition must be 50% or greater to qualify for ERV Incentive
 2. The airflow capacity for Incentive calculations shall be the actual exhaust air flow or outside air flow, whichever is least, as specified in the ERV equipment specifications.
 3. AHRI's 100% Nominal Airflow capacity will be used for the airflow Incentive calculations if actual air flow exceeds AHRI's listed 100% Nominal Airflow.
 4. The Net Total Thermal Effectiveness from AHRI's 75% Airflow Conditions shall be used if ERV equipment actual outside or exhaust air flow specifications are 75% or less of AHRI Nominal Airflow capacity.
 5. A copy of air flow design submittal for the ERV must be received by Gulf Power prior to Incentive payment processing.
 6. Incentive Program does not apply to new construction projects that required ERV by code

DCV Incentive Tables

Demand Control Ventilation Incentive Table - HVAC Systems

Incentive Retrofit \$663 per Sensor Available for Incentive

Sensors Available for Incentive Not to Exceed Total Installation Cost / 500 (rounded down nearest whole number)

Notes:

1. Demand Control Ventilation (DCV) system must be designed to reduce the outside air flows for a facility at low occupancy, but not to be less than required by all government statues, codes, ordinances, and accepted engineering practices.
2. The Incentive payment is limited 1 DCV sensor per zone unless approved by Gulf Power Specialist
3. The building's DCV system shall modulate the outside air flow based on air flow measurements and occupancy sensor readings.
4. Occupancy sensors are typically required for each common air conditioned zone and meeting room.
5. The DCV system shall balance the outside air flows with exhaust flows for proper building pressurization at all load and occupancy conditions.
6. Incentive does not apply to new construction projects that required DCV by code.
7. Total installation cost includes sensors, labor, equipment (wiring, dampers,etc), and programming/engineering costs.

Kitchen Demand Control Ventilation Incentive Table

Hood Exhaust Air			Incentive
			Dollars
0	< CFM ≤	300.00	\$ 168
300	< CFM ≤	600.00	\$ 506
600	< CFM ≤	900.00	\$ 844
900	< CFM ≤	1,200.00	\$ 1,181
1200	< CFM ≤	1,500.00	\$ 1,519
1500	< CFM ≤	1,800.00	\$ 1,857
1800	< CFM ≤	2,100.00	\$ 2,194
2100	< CFM ≤	2,400.00	\$ 2,532
2400	< CFM ≤	2,700.00	\$ 2,870
2700	< CFM ≤	3,000.00	\$ 3,207
3000	< CFM ≤	3,300.00	\$ 3,545
3300	< CFM ≤	3,600.00	\$ 3,883
3600	< CFM ≤	3,900.00	\$ 4,221
3900	< CFM ≤	4,200.00	\$ 4,557
4200	< CFM ≤	4,500.00	\$ 4,895
4500	< CFM ≤	4,800.00	\$ 5,234
4800	< CFM ≤	5,100.00	\$ 5,571
5100	< CFM ≤	5,400.00	\$ 5,909
5400	< CFM ≤	5,700.00	\$ 6,247
5700	< CFM ≤	6,000.00	\$ 6,584

Hood Exhaust Air			Incentive
			Dollars
6,000	< CFM ≤	7,750	\$ 7,738
7,750	< CFM ≤	9,500	\$ 9,708
9,500	< CFM ≤	11,250	\$ 11,678
11,250	< CFM ≤	13,000	\$ 13,647
13,000	< CFM ≤	14,750	\$ 15,617
14,750	< CFM ≤	16,500	\$ 17,587
16,500	< CFM ≤	18,250	\$ 19,556
18,250	< CFM ≤	20,000	\$ 21,526
20,000	< CFM ≤	21,750	\$ 23,496
21,750	< CFM ≤	23,500	\$ 25,466
23,500	< CFM ≤	25,250	\$ 27,436
25,250	< CFM ≤	27,000	\$ 29,406
27,000	< CFM ≤	28,750	\$ 31,376
28,750	< CFM ≤	30,500	\$ 33,344
30,500	< CFM ≤	32,250	\$ 35,315
32,250	< CFM ≤	34,000	\$ 37,285
34,000	< CFM ≤	35,750	\$ 39,254
35,750	< CFM ≤	37,500	\$ 41,225
37,500	< CFM ≤	39,250	\$ 43,194
39,250	< CFM ≤	41,000	\$ 45,164

For kitchen DCV a copy of the hood manufacturer specifications listing airflow capacities of the exhaust and make-up air fans must be submitted. When not available a copy of the Test and Balance Report, showing both exhaust and make-up airflows for the fans can be substituted for the hood manufacturer specifications.